

BUILDING DIVISION—BUILDING INSPECTOR'S REPORT CARD

*PH-F49-52*

**TYPE BUILDINGS**

*M-23-73*

PERMIT NO. <i>B-29474</i>	LOCATION <i>1831 - J. Street</i>
DATE <i>6/20/50</i>	PURPOSE <i>Erect office bldg.</i>
ZONE <i>com.</i>	OWNER <i>G. W. Douglas</i>
	ARCH'T. <i>Guth &amp; Schmidt</i>
	CONTR. <i>Guth &amp; Schmidt</i>

VAL. <i>20,000<sup>00</sup></i>	STORIES <i>1</i>	ROOMS	APTS.	SIZE
---------------------------------	---------------------	-------	-------	------

LIGHT SHAFTS		ELEVATOR SHAFTS	
VENT SHAFTS		BOILER ROOMS	
OWNER'S INSPECTOR		SPRINKLER SYSTEM	
LATH		GAS VENTS	
FIRE ESCAPES		CHIMNEYS	
STAND PIPES		SKYLIGHTS	

DATE	CONDITION OF WORK—REMARKS
6/22/50	Form Insp. (V. E. Buckius)
8/10/50	Frame " "
8/22/50	Lath " (Not nailed properly—only 3 nails per end) V. E. Buckius
	<div style="display: flex; justify-content: space-between;"> <span data-bbox="338 1000 488 1047">COMPLETE AND O. K.</span> <span data-bbox="1333 1020 1492 1044">INSPECTOR</span> </div>