

BUILDING DIVISION—BUILDING INSPECTOR'S REPORT CARD

TYPE VII BUILDINGS

PERMIT NO. <i>272</i>	LOCATION <i>5637-37</i>		
DATE	PURPOSE <i>Addn Repair</i>	ROOMS <i>2</i>	APTS.
ZONE <i>107</i>	OWNER <i>J W Foster</i>		PHONE
	ARCH'T		
	CONT'R <i>Ormond</i>		
	VAL. <i>1000</i>	STORIES	SIZE

FOUNDATION	STORY	BSMT	1	2	3	ROOF		
Ex Wall	Jolts						Chimneys	Cement Tests
	Beams and Girders						Fire Place	
Int Wall	Studs and Columns						Gas Water Heater	Window Courts
	Bridging Fire Stops						Heater Closet	
Floors	Fire Escape Stand Pipes						Furnace	
	Metal Lath						Boiler Room	
	Stairs						Elevator Shaft	



DATE	CONDITION OF WORK—REMARKS
5/19/27	1 <sup>st</sup> INSP. FORMS. <sup>Noted out to install 3-4x6 Girders under old post for support of 2x4 joists and 4x4 posts on brackets with 6" C.</sup> <i>AWC</i>
5/20/27	2 <sup>nd</sup> INSP. Contractor put in add. 2x6's under for support of old post. <i>AW Campbell</i>
5/24/27	3 <sup>rd</sup> INSP. PLASTERBOARD. W. & C. on 2 <sup>nd</sup> Rm Addition. <i>AW Campbell</i>
7/9/27	4 <sup>th</sup> INSP. Additions to Dwy Completed. <i>AW Campbell</i>
7/9/27	COMPLETED AND O. K. <i>Alden W Campbell</i> <div style="text-align: right;">Inspector</div>