

BUILDING DIVISION—BUILDING INSPECTOR'S REPORT CARD

TYPE VII BUILDINGS

PERMIT NO. 4748	LOCATION <i>Street 9 2nd</i>	914-23 St	
DATE	PURPOSE <i>Full Apt Hse</i>	ROOMS 36	APTS. 18
PAID JUL 8 1929 SACRAMENTO BUILDING DIVISION	OWNER <i>John Hernandez</i>	PHONE 3040 1/2 - 33	
	ARCHT <i>[Signature]</i>		
	CONTR <i>[Signature]</i>		
VAL.	<i>3000 -</i>	STORIES 3	SIZE 31' x 73' - 31

FOUNDATION	STORY	BSMT	1	2	3	ROOF	Chimneys	Cement Tests
Ex Wall	Joists							
Int Wall	Beams and Girders						Fire Place	
	Studs and Columns						Gas Water Heater	
Piers	Bridging						Heater Closet	
	Fire Escape Stand Pipes						Furnace	Window Courts
	Metal Lath						Boiler Room	
	Stairs						Elevator Shaft	

DATE	APARTMENT HOUSE CONDITION OF WORK—REMARKS
7/10/29	^{Now occupying for basement} Preliminary Insp. Cont. removed trees on lot. A.W. Campbell ✓
7/16/29	1 ST N.S.P. & Basement Wall Forms OK A.W. Campbell
7/17/29	1 ST " Dwarf Walls in Basement and ^{Front Main} Walls OK A.W. Campbell Made Contractors to hurry removal of dirt from street sidewalk ^{not} clear
7/23/29	" " make all framing shoring of 1 ST STORY 3x4 or equal ^{not} A.W.C.
8/12/29	2 ND N.S.P. FRAME FOR 1 ST STORY ONLY OK A.W. Campbell
8/14/29	3 " 1 ST STORY Earth OK & in place P.H. Reuter
8/19/29	4 N.S.P. = 2 ND + 3 RD story frame in place OK P.H. Reuter
8/27/29	3 RD story Bath on 3 story OK P.H. Reuter
9/10/29	3 RD N.S.P. Double Scratch Coat for 1 ST STORY A.W. Campbell State Law Requires 1 1/2" thickness 3 RD story and houses
9/16/29	3 RD N.S.P. 1 ST Ceiling of Metal with ^{Fireproof} concrete on A.W. Campbell ^{Not} Fireproofing East Walls. Made Cont. to provide guard.
9/17/29	3 RD N.S.P. ^{North} side of 2 ND STORY OK A.W. Campbell 3 RD " ^{North} ^{side} ^{of} ^{2ND STORY} OK A.W. Campbell 3 RD " ^{North} ^{side} ^{of} ^{2ND STORY} OK P.H. Reuter
10/17/29	Temporary final for hook up only P.H. Reuter COMPLETED AND O. K. INSPECTOR