

BUILDING DIVISION—BUILDING INSPECTOR'S REPORT CARD

TYPE VII BUILDINGS

PERMIT NO. *4761*

LOCATION

*5590-17*

PURPOSE

*Residential w/dep.*

ROOMS

APTS.

OWNER

*J. Conroy Co.*

PHONE

ARCH'T

CON'T'R

*J. Richards*

TAL.

*300*

STORIES

SIZE

**ISSUED**  
**MAR 19**  
**ZONE 1929**  
**SACRAMENTO**  
**BUILDING DIVISION**

FOUNDATION	STORY	BSMT	1	2	3	ROOF	Chimneys	Cement Tests
Ex Wall	Jolts							
	Beams and Girders						Fire Place	
Int Wall	Studs and Columns						Gas Water Heater	
	Bridging Fire Stops						Heater Closet	
Piers	Fire Escape Stand. Pipes						Furnace	Window Courts
	Metal Lath						Boiler Room	
	Stairs						Elevator Shaft	



DATE  
TIME  
MATERIALS  
LABOR  
EQUIPMENT  
REMARKS

DATE	CONDITION OF WORK—REMARKS
4/2/29	Made Inspection of Exterior of Dwg. Old - "Hoffite" Stucco Plaster removed from wooden lath - then covered with 2 Ply Bldg Paper and 18 gauge Galv. wire & Gum Furring nails put on in place of same ready for Cement Stucco Plaster. H. H. Campbell
	COMPLETED AND O. K. <span style="float: right;">INSPECTOR</span>

