

CITY OF SACRAMENTO
1231 I Street, Sacramento, CA 95814

Permit No: 0002072
Insp Area: 1

Site Address: 1420 29TH ST SAC
Parcel No:

Housing (Y/N):

Sub-Type: ACOM
N

CONTRACTOR
TGL ENTERPRISES
POBOX 1136
FAIR OAKS 95628

OWNER
DON RAPASURA
5950 CAVITT STALLMAN RD
GRANITE BAY CA 95746

ARCHITECT

Nature of Work: REMODEL:904SF ADDITION AND SITE WORK INCL NEW PARKING LOT
TO JIMBOYS RESTARAUNT

CONSTRUCTION LENDING AGENCY : I hereby affirm under penalty of perjury that there is a construction lending agency for the performance of the work for which this permit is issued (Sec. 3097, Civ. C).

Lender's Name _____ Lender's Address _____

LICENSED CONTRACTORS DECLARATION: I hereby affirm under penalty of perjury that I am licensed under provisions of Chapter 9 (commencing with section 7000) of Division 3 of the Business and Professions Code and my license is in full force and effect.

License Class B-C10 License Number 618497 721154 Date 7-10-00 Contractor Signature [Signature]

OWNER-BUILDER DECLARATION: I hereby affirm under penalty of perjury that I am exempt from the contractors License Law for the following reason (Sec. 7031.5, Business and Professions Code; any city or county which requires a permit to construct, alter, improve, demolish, or repair any structure, prior to its issuance, also requires the applicant for such permit to file a signed statement that he or she is licensed pursuant to the provisions of the Contractors License Law (Chapter 9 (commencing with Section 7000) of Division 8 of the Business and Professions Code) or that he or she is exempt therefrom and the basis for the alleged exemption. Any violation of Section 7031.5 by any applicant for a permit subjects the applicant to a civil penalty of not more than five hundred dollars (\$500.00):

I, as a owner of the property, or my employees with wages as their sole compensation, will do the work, and the structure is not intended or offered for sale (Sec. 7044, Business and Professional Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who does such work himself or herself or through his/her own employees, provided that such improvements are not intended or offered for sale. If, however, the building or improvement is sold within one year of completion, the owner-builder will have the burden of proving that he/she did not build or improve for the purpose of sale.)

I, as owner of the property, am exclusively contracting with licensed contractors to construct the project (Sec. 7044, Business and Professions Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who contracts for such projects with a contractor(s) licensed pursuant to the Contractors License Law).

I am exempt under Sec. _____ B & PC for this reason: JUL 10 2000
Date _____ Owner Signature _____

IN ISSUING THIS BUILDING PERMIT, the applicant represents, and the city relies on the representation of the applicant, that the applicant verified all measurements and locations shown on the application or accompanying drawings and that the improvement to be constructed does not violate any law or private agreement relating to permissible or prohibited locations for such improvements. This building permit does not authorize any illegal location of any improvement or the violation of any private agreement relating to location of improvements.

I certify that I have read this application and state that all information is correct. I agree to comply with all city and county ordinances and state laws relating to building construction and hereby authorize representative(s) of this city to enter upon the abovementioned property for inspection purposes.

Date 7-10-00 Applicant/Agent Signature [Signature]

WORKER'S COMPENSATION DECLARATION: I hereby affirm under penalty of perjury one of the following declarations:
I have and will maintain a certificate of consent to self-insure for workers' compensation as provided for by Section 3700 of the Labor Code, for the performance of work for which the permit is issued.

TGL I have and will maintain workers' compensation insurance, as required by Section 3700 of the Labor Code, for the performance of the work for which this permit is issued. My workers' compensation insurance carrier and policy number are:

Carrier STATE FUND Policy Number 1858677-00 Exp Date 07.01.01

(This section need not be completed if the permit is for \$100 or less) I certify that in the performance of the work for which this permit is issued, I shall not employ any person in any manner so as to become subject to the workers' compensation laws of California and agree that if I should become subject to the workers' compensation provisions of Section 3700 of the Labor Code, I shall forthwith comply with those provisions.

Date 7-10-00 Applicant Signature [Signature]

WARNING FAILURE TO SECURE WORKER'S COMPENSATION COVERAGE IS UNLAWFUL AND SHALL SUBJECT AN EMPLOYER TO CRIMINAL PENALTIES AND CIVIL FINES UP TO ONE HUNDRED THOUSAND DOLLARS (\$100,000) IN ADDITION TO THE COST OF COMPENSATION. DAMAGES AS PROVIDED FOR IN SECTION 3706 OF THE LABOR CODE, INTEREST AND ATTORNEY'S FEE.

THIS PERMIT SHALL EXPIRE BY LIMITATION IF WORK IS NOT COMMENCED WITHIN 180 DAYS.

CITY OF SACRAMENTO

CERTIFICATE OF OCCUPANCY

For Information Contact (916) 264-5716

Building Address: 1420 - 29TH ST Permit No. 00-02072

Building Use: RESTAURANT DBA: JIMBOYS Occupancy: A3

Building Owner: DON RAPISURA Construction Type: V-N

Owner Address: 5950 CAVITT STALLMAN RD Sprinkled? [] Yes [] No

Portion of Building Occupied: ENTIRE Area: 1931 Sq. Ft.

3/19/01 Willie Harris DENNIS RICHARDSON
Date By:Print Sign CITY BUILDING OFFICIAL

[Finaled By:GTD,MJS,JZB,MG,CP]

This Certificate, issued pursuant to the requirements of Section 109 of the Uniform Building Code, certifies that at time of issuance the described portion of the building has been inspected for compliance with the Uniform Building Code, as adopted per Title 15 of the Sacramento City Code for the group and division of occupancy and use for which the proposed occupancy is classified. Issuance of this certificate shall not be construed as an approval of a violation of any Codes, or Federal, State and City Laws or Ordinances. Certificates presuming to give authority to such violation shall not be valid. This certificate shall be posted in a conspicuous place on the premises and shall not be removed except by the City Building Official. No changes shall be made in the character of occupancy or use without approval of the City Building Official.

POST IN A CONSPICUOUS PLACE

**CITY OF SACRAMENTO
APPLICATION FOR COMMERCIAL BUILDING PERMIT**

DEVELOPMENT SERVICES DIVISION
PERMIT SERVICES SECTION

1231 I Street, Rm. 200
Sacramento, CA 95814 (916) 264-7619 FAX 264-7046

ACTIVITY # 0002072 Insp. Area 1C

Applicant **MUST** complete ALL Unshaded areas

ADDRESS 1420 29th St Suite _____
PARCEL # 007-0273-023

CONTACT		LICENSED CONTRACTOR Lic No. # <u>654115</u>	
Name _____	Address _____	Name <u>FINNED</u>	Address <u>1500 Bu. 1979 Road</u>
Phone _____ FAX _____	E-mail _____	Phone <u>99-050</u> FAX <u>719</u>	E-mail _____
ARCHITECT/ENGINEER		OWNER	
Name _____	Address _____	Name <u>DON RAPISURA</u>	Address <u>5950 CAVITT STALLMAN RD.</u>
Phone _____ FAX _____	E-mail _____	Phone _____ FAX _____	E-mail _____

→ Will permittee have any employees on the jobsite? No Yes → INSURANCE CO: _____
→ WORKER'S COMPENSATION POLICY # _____ EXPIRATION DATE: _____

NATURE OF WORK IN DETAIL: ADDITION - ADD PARKING
904 sq ft + CANOPIES + PATIO COV. 384 SF


OCCUPANT/TENANT: JIMBOYS VALUATION: \$250,000.00

FLOOD STATUS: <u>NR</u>		S.C.A.T. <u>X11, X12</u>							
JOB DESCRIPTION	BLDG	SHELL	APT	TI()	REM()	SW	FIRE	<u>ADD</u>	OTH
INSPECTION DISCIPLINES		<u>BLDG</u>	<u>MECH</u>	<u>PLUMB</u>	<u>ELEC</u>	<u>SITE</u>	<u>FIRE</u>		
# Stories	1st flr Area	Total Area	Use Zone	Occp Group	Const type	Fire Req. Y/N	Fed Code	Vio. File	
<u>1</u>	<u>1931 new total</u>			<u>A3</u>	<u>V-N</u>	SPR ALARM	<u>18</u>	[H]	[Quad]
<u>(B)</u>	<u>(L)</u>	<u>(P)</u>	<u>(M)</u>	<u>(E)</u>	<u>(F)</u>	<u>(S)</u>	<u>(D)</u>	PW	UTIL
							<u>BL</u>		

COMMENTS: SUBMIT TO HEALTH DEPT BRING RECAP
1st submittals signed by health 3/2/00 BL
GATES KNOWBOX?

REGIONAL SANITATION FEES? Yes No HEALTH DEPARTMENT? Yes No
 WATER FLOW TEST FOR NEW BUILDINGS OR ADDITIONS? Provided Faxed

90"



June 20, 2000

RECEIVING FAX : 967-0125

SENDING FAX : 875-6253

TO: **TIM LAFFOON**
TGL ENTERPRISES

FROM: **DOLORES ROSS**
SACRAMENTO REGIONAL COUNTY SANITATION DISTRICT

PHONE NUMBER: 875-6679

RE: **SEWER FACILITY IMPACT FEES**
1420 - 29TH ST.

APN: **007-0273-023**
Plan Check 000-2072

Handwritten initials: ASK

The Sewer Facility Impact Fees due for a 904 sq.ft. addition to an existing "Jim Boy's" restaurant at the above address are as follows:

Impact to Sac. Regional County San. District	\$9,540
--	---------

This fee is based solely upon the size of the addition to the restaurant. Payment can be made at 827 Seventh Street, Room 105, Window 11. If you have any further questions, please feel free to call me at 875-6679.

Handwritten signature: Dolores

cc: Barbara Larsen, City of Sacramento
Joe Leford, TGL Enterprises

This fee is also subject to adjustment if the data supplied is changed.

www.srcsd.com

e-mail: rossd@pwa.co.sacramento.ca.us

Date of Request: _____

By: _____

CITY OF SACRAMENTO DEVELOPMENT SERVICES DIVISION
PLANNING AND ZONING INFORMATION REQUEST

Project Address: 1420 29th St

Assessor's Parcel Number: 007-0273-023

Previous Use: Restaurant

Description of Request/Proposed Use: Restaurant expansion

Is This a Change of Use? _____

Zoning Designation: C2SPD

Prior Applications for Project Site(P#, Z#, DRPB#): Alhambra Center

Z99038 - DR 99-057

Comments: _____

per approved plans

Are There Any Planning Issues?: (circle one) YES NO

* Staff Site Plan Check Required? (Circle one) YES NO

* Field Inspection Required? (Circle one) YES NO

* Design Review/Preservation Required?: (Circle one) YES NO

Planning Review by/Date: [Signature]

9-28-01

A list of items that must be reviewed by Planning is provided on the reverse side of this form.

MICROFILM AFTER FINAL

Date of Request: 3/2/00
By: DAI

CITY OF SACRAMENTO DEVELOPMENT SERVICES DIVISION
PLANNING AND ZONING INFORMATION REQUEST

Project Address: 1420 29th St

Assessor's Parcel Number: 007 - 0273 - 023 + 024

Previous Use: _____

Description of Request/Proposed Use: Restaurant Addition

Is This a Change of Use? _____

Prior Applications for Project Site(P#, Z#, DRPB#): _____
Zoning Designation: DR 99-057, 99-121
299-038

Comments: See conditions of
299-038 & DR 99-057
(LLM, SP, MOD)

Are There Any Planning Issues?: (circle one) YES NO

- * Staff Site Plan Check Required? (Circle one) YES NO
- * Field Inspection Required? (Circle one) YES NO
- * Design Review/Preservation Required?: (Circle one) YES NO

Planning Review by/Date: W. J. Ibrak 3/2/00

A list of items that must be reviewed by Planning is provided on the reverse side of this form.

MICROFILM AFTER FINAL

Certification of Compliance

School District Development Fees

(Print or Type) If Printing, press hard for four copies

PART I To be completed by the APPLICANT

OWNER'S NAME Don D. Rapiaura
 OWNER'S ADDRESS 5950 Cavitt Stallman Road, Granite Bay, California
 PROJECT ADDRESS 1420 29th Street, Sacramento, California
 PARCEL NUMBER 007 0273 024000 LOT NO. _____
 SUBDIVISION NAME _____
 NUMBER OF UNITS _____

Upon payment of the fees listed below, a 90-day approval period commences upon which the applicant paying the fees may protest such fees. Any failure to file such protest within the 90-day period shall result in forfeiture of any rights to challenge such fees, through litigation or otherwise.

APPLICANT'S SIGNATURE [Signature]
 TITLE OF APPLICANT Owner
 DATE 6-19-00 PHONE NUMBER 916-564-8226 or 791-1904

PART II To be completed by BUILDING DEPARTMENT

PLAN IDENTIFICATION NUMBER 0002072
 BUILDING TYPE
 RESIDENTIAL () APARTMENT/CONDOMINIUM () COMMERCIAL/INDUSTRIAL ()
 SQUARE FEET OF CHARGEABLE BUILDING AREA 904
 SIGNATURE KIM ROBINSON
 TITLE BUILDING INSPECTOR I DATE 06.19.00

PART III To be completed by SCHOOL DISTRICT

SCHOOL DISTRICT SLUSD
 DISTRICT CERTIFICATION NO. 4-15

EXEMPT	COMMENTS
RESIDENTIAL/APT/CONDO _____	SQ FT X \$ _____ = \$ _____
COMMERCIAL/INDUSTRIAL <u>904</u>	SQ FT X \$ <u>.28</u> = \$ <u>253.12</u>
OTHER FEE _____ TYPE _____	SQ FT X \$ _____ = \$ _____
TOTAL FEES COLLECTED _____	= \$ <u>253.12</u>

This Certification covers only the amount of square footage indicated above. Any additions or corrections to the square footage for this project will require an amendment to the Certificate of Compliance.

As the authorized school district official, I hereby certify that the requirements of Government Code Section 65995 and any other authorized requirements have been complied with by the above signed applicant.

AUTHORIZED SCHOOL DISTRICT OFFICIAL

SIGNATURE [Signature]
 TITLE CIVIL ENGINEER DATE 7/5/00

Original: School District 1st copy: School District 2nd copy: Building Department 3rd copy: Applicant

COUNTY SANITATION DISTRICT NO. 1
 SACRAMENTO REGIONAL COUNTY SANITATION DISTRICT
SEWER IMPACT FEE
 PERMIT AND CALCULATION SHEET

APPLICATION NO: *City*
 GENERAL INFORMATION

BLDG PERMIT NO:
 THIS PERMIT GOOD ONLY WHEN
 VALIDATED BY THE CASHIER
HB 261250 7-5-06

THIS PERMIT TO CONNECT EXPIRES
 ONE YEAR FROM DATE OF ISSUANCE

FEE CALCULATION		BUILDING USE	
INSPECTION		RESIDENTIAL	SF <input type="checkbox"/> MF <input type="checkbox"/>
CSD-1		COMMERCIAL USE	UNITS
SRCSD	<i>9540</i>	<i>Fees for a</i>	
CONSTRUCTION		<i>209 sq. ft.</i>	
IN-LIEU		<i>addition</i>	
TOTAL FEE	<i>9540</i>		

APN: *007-0273.023*
 DESCRIPTION/ SUBDIVISION: *N/A* LOT: *N/A*

PROPERTY ADDRESS: *1400 - 29th St*

OWNER: *Don D. RUTISIERA*

MAILING ADDRESS: *9750 Parth Stallman Rd.*

CITY-STATE-ZIP: *Sikeait's Bay Ca* PHONE: *548 8016*

ADDITIONAL FEES MAY BE DUE IF CHANGES IN USE INCREASE SEWER IMPACT.

APPLICANT SIGNATURE: *[Signature]*

CONSOLIDATED UTILITY BILLING USE ONLY

DATE: _____ INPUT: _____ START: _____

CIRCO System Balance, Inc.

AIR • HYDRONIC • TEMPERATURE • SOUND • SYSTEM SURVEY

8167 BELVEDERE AVENUE, SUITE E

SACRAMENTO, CALIFORNIA 95826

(916) 454-9103

COMPLETION DATE

JOB NO.

7555

JOB DESCRIPTION:

Jimboy's Tacos

1430 29th Street

CONTRACTOR:

RPI

ARCHITECT:

ENGINEER:

RPI

TEST PERFORMED BY:

John C.

*Done by
@ RPI*



CHARTER MEMBER OF ASSOCIATED AIR BALANCE COUNCIL

TABLE OF CONTENTS

SECTION

DESCRIPTION

REMARKS CONCERNING BALANCING PROCEDURES

1

2 AC-1 outlets # 1 to 10

3 AC-2 outlets # 11 to 15

4 EF-1 Hood #1

5 EF-2 Hood #2

6 EF-3 Hood #3

7 MAU-1

8 MAU-2

SECTION ONE

NOTE: PICK ONE ONLY - MARK THROUGH THOSE NOT WANTED.

1. (A) THE TOTAL AIR DELIVERY OF EACH FAN WAS ESTABLISHED BY OUTLET TOTAL AND DOES NOT INCLUDE POSSIBLE DUCT LEAKAGE.

(B) THE TOTAL AIR DELIVERY OF EACH ^{Hood} FAN WAS ESTABLISHED BY...

- (1) ~~PITOT TRAVERSE READINGS AT THE FAN~~
- (2) ~~BY ANEMOMETER READINGS AT THE COIL~~
- (3) ~~ANEMOMETER READINGS AT THE COIL AND FILTER BANK~~
- (4) ANEMOMETER READINGS AT THE FILTER BANK

~~DURING BALANCE OPERATIONS, A FALSE FILTER STATIC DROP WAS IMPOSED BY BLOCKING PORTIONS OF THE FILTERS (SEE EACH FAN TEST SHEET FOR ACTUAL DROP). AFTER THE FAN SYSTEMS WERE BALANCED, THE FILTER BLOCKING WAS REMOVED.~~

~~THE SCHEMATIC LOCATED IN THE FRONT OF EACH SECTION IS KEYED TO THE CORRESPONDING FAN AND OUTLET TEST SHEETS.~~

4. ALL (BALANCE) ~~(CEILING SUPPLY DIFFUSERS)~~ FACTORS WERE OBTAINED FROM THE MANUFACTURER'S DATA AND APPLIED ACCORDING TO THEIR SUGGESTED METHOD.

5. BALANCE FACTORS FOR SIDEWALL SUPPLY AND RETURN ~~EXHAUST~~ GRILLES WERE CALCULATED FROM CORE AREA AND MEASURED WITH A 4" ROTATING VANE ANEMOMETER.

	NAME	TYPE
CEILING SUPPLY DIFFUSERS ARE	_____	_____
SIDEWALL SUPPLY REGISTERS ARE	_____	_____
RETURN EXHAUST REGISTERS ARE	_____	_____

NOTE: INCLUDE THIS PARAGRAPH ONLY IF SCOOP IS USED

6. (A) INLET AND OUTLET AIR QUANTITIES, WITH PERFORATED PLATES, WERE MEASURED BY SPECIAL AIR SCOOP. SEE DATA SHEET THIS SECTION.

~~(B) TROFFER AIR QUANTITIES WERE MEASURED BY SPECIAL AIR SCOOP. SEE DATA SHEET THIS SECTION.~~

~~7. FOR FURTHER NOTES CONCERNING BALANCE, SEE PAGE ONE OF EACH SECTION.~~

NOTE: #8 (NO MATTER HOW MANY NOTES ARE ADDED) IS LAST ITEM TYPED.

8. FOLLOWING THIS SHEET ARE:
- 1. SYMBOL SHEET
 - 2. SPECIAL SCOOP DATA SHEET (A)
 - 3. SPECIAL SCOOP DATA SHEET (B)
 - 4. INSTRUMENT CORRECTION CURVES

CIRCO SYSTEM BALANCE, INC.

SB JOB NO. _____
 SECTION _____ PAGE _____
 DATE 2-6-01

FAN & OUTLET TEST SHEET

AREA SERVED Jimboy's Tacos Dining Area UNIT AC-1

MOTOR NAMEPLATE DATA

MFG _____ FR _____
 HP 3/4 V 208 FLA 5.4
 PH 1 SF _____ RPM _____

SHEAVE DATA:

DIA Direct SHAFT Drive
 ADJ _____ % _____ FIXED _____

FAN NAMEPLATE DATA

MFG Rheem
 MODEL RHKA-A060
 TYPE Package
 SIZE _____

SHEAVE DATA:

DIA _____ SHAFT _____
 BELTS _____

DATA ITEM	TEST 1	TEST 2	TEST 3
VOLTS	<u>210</u>		
AMPS	<u>3.7</u>		
BHP	<u>.51</u>		
RPM			
SP -	<u>.10</u>		
SP +	<u>.16</u>		
ETSP	<u>.26</u>		
FILTER SP	<u>.06</u>		
CFM TOTAL	<u>1311</u>		
CFM RA	<u>1211</u>		
CFM OA			

FAN DESIGN DATA

CFM _____ SP _____ RPM _____ BHP _____
 No O.A. * Read only *

ROOM	OPENING			FAC TOR	DESIGN		TEST 1		TEST 2		TEST 3	
	NO.	TYPE	SIZE		FPM	CFM	FPM	CFM	FPM	CFM	FPM	CFM
					<u>Supply</u>							
1)	1	SWS		.39	110	412	161					
	2	↓		.39	110	245	96					
	3	↓			110	252	98					
	4	SWS	5x12 1/2		110	261	102					
	5	↓			110	240	94					
	6	↓			110	256	100					
	7	CO		1.0	160		160					
	8	↓			160		175					
	9	↓			160		180					
	10	↓			160		145					
						<u>1300</u>	<u>1311</u>					
					<u>Return</u>							
	R1	SVR	22x13	1.99			342	681				
	R2	CO		1.0				530				
						<u>1300</u>		<u>1211</u>				

REMARKS: 1) No grill installed. 2/6

CIRCO SYSTEM BALANCE, INC.

SB JOB NO. _____
 SECTION _____ PAGE _____
 DATE 2-6-01

FAN & OUTLET TEST SHEET

AREA SERVED Jim boy's Tacos Kitchen Area UNIT AC-2

MOTOR NAMEPLATE DATA

MFG _____ FR _____
 HP 1/2 V 208 FLA 2.8
 PH L SF _____ RPM _____

SHEAVE DATA:

DIA Direct SHAFT Drive
 ADJ _____ % _____ FIXED _____

FAN NAMEPLATE DATA

MFG Armstrong Air
 MODEL P6E10B360075
 TYPE Package
 SIZE _____

SHEAVE DATA:

DIA _____ SHAFT _____
 BELTS _____

DATA ITEM	TEST 1	TEST 2	TEST 3
VOLTS	209	209	
AMPS	1.9	1.9	
BHP	.34	.34	
RPM	_____	High	
SP -	.06	.06	
SP +	.12	.12	
ESP	.18	.18	
FILTER SP	.06	.06	
CFM TOTAL	625	555	
CFM RA	600	550	
CFM OA	_____	_____	

FAN DESIGN DATA

CFM 570 SP _____ RPM _____ BHP _____
 NO O.A. * Read only *

ROOM	OPENING			FAC TOR	DESIGN		TEST 1		TEST 2		TEST 3	
	NO	TYPE	SIZE		FPM	CFM	FPM	CFM	FPM	CFM	FPM	CFM
<u>Supply</u>												
	11	CO		1.0	150	190	190	155				
	12	↓		↓	150	220	220	145				
	13	↓		↓	110	75	75	110				
	14	↓		↓	110	120	120	105				
	15	↓		↓	50	20	20	40				
					570	625	625	555				
<u>Return</u>												
	R3	CR		1.0	285	220	220	270				
	R4	CR		1.0	285	380	380	280				
					570	600	600	550				

REMARKS: _____

CIRCO SYSTEM BALANCE, INC.

SB JOB NO. _____
 SECTION _____ PAGE _____
 DATE 2-6-01

FAN & OUTLET TEST SHEET

AREA SERVED Jimboy's Tacos Hood# 1 UNIT EF-1

MOTOR NAMEPLATE DATA

MFG Dayton FR 56
 HP 3/4 V 115 FLA 11.4
 PH 1 SF 1.23 RPM 1725

SHEAVE DATA:

DIA 1 1/2 SHAFT 5/8
 ADJ % FIXED

FAN NAMEPLATE DATA

MFG Dayton
 MODEL 4N894A
 TYPE Curb
 SIZE

SHEAVE DATA:

DIA AK39 SHAFT 7/8"
 BELTS (1) 4L-210

DATA ITEM	TEST 1	TEST 2	TEST 3
VOLTS	120	120	
AMPS	8.6	9.9	
BHP	.57	.65	
RPM	1242	1341	
SP -	/	/	
SP +	/	/	
TSP	/	/	
FILTER SP	/	/	
CFM TOTAL	2066	2201	
CFM RA	-	-	
CFM OA	-	-	

FAN DESIGN DATA

CFM 2175 SP RPM BHP

ROOM	OPENING			FAC TOR	DESIGN		TEST #		TEST # 1		TEST # 2	
	NO	TYPE	SIZE		FPM	CFM	FPM	CFM	FPM	CFM	FPM	CFM
E1	AR	18x18		207	254	167	345	216	447	233	482	
E2	↓	↓		↓	254	160	342	243	503	254	526	
E3	↓	↓		↓	254	181	387	255	528	283	586	
E4	↓	↓		↓	254	185	396	284	588	293	607	
						2175	1470		2066		2201	
							(68%)		(95%)		(102%)	

REMARKS

Factor = .92

CIRCO SYSTEM BALANCE, INC.

SB JOB NO. _____
 SECTION _____ PAGE _____
 DATE 2-6-01

FAN & OUTLET TEST SHEET

AREA SERVED Hood #2 UNIT EF-2

MOTOR NAMEPLATE DATA

MFG Dayton FR 56
 HP 1/4 V 315 FLA 11.4
 PH 1 SF 1/25 RPM 1725

SHEAVE DATA:
 DIA 1 1/2 SHAFT 5/8
 ADJ % FIXED

FAN NAMEPLATE DATA

MFG Dayton
 MODEL 4H894A
 TYPE Curve
 SIZE

SHEAVE DATA:
 DIA AH39 SHAFT 7/8
 BELTS (1) 4L-210

DATA ITEM	TEST 1	TEST 2	TEST 3
VOLTS	118	118	
AMPS	8.1	9.3	
BHP	.53	.61	
RPM	1183	1272	
SP -	/	/	
SP +	/	/	
TSP	/	/	
FILTER SP	/	/	
CFM TOTAL	2088	2300	
CFM RA	-	-	
CFM OA	-	-	

FAN DESIGN DATA

CFM 2175 SP RPM BHP

ROOM	OPENING			FAC TOR	DESIGN		TEST 1		TEST #1		TEST #2	
	NO	TYPE	SIZE		FPM	CFM	FPM	CFM	FPM	CFM	FPM	CFM
							Stand off					
E5	AR	18x18	2.07	254		210	449	305	631	216	654	
E6	↓	↓	↓	254		174	372	261	540	293	607	
E7	↓	↓	↓	254		21	366	240	497	258	534	
E8	↓	↓	↓	254		37	293	203	420	244	505	
						2175	1480		2088		2300	
							68%		76%		106%	

REMARKS _____

CIRCO SYSTEM BALANCE, INC.

SB JOB NO. _____
 SECTION _____ PAGE _____
 DATE 2-6-01

FAN & OUTLET TEST SHEET

AREA SERVED Hood # 3 UNIT EF-3

MOTOR NAMEPLATE DATA

MFG Dayton FR 56
 HP 3/4 V 115 FLA 11.4
 PH 1 SF 1.25 RPM 1725

SHEAVE DATA:
 DIA 1 1/2 SHAFT 5/8"
 ADJ 0 % FIXED

FAN NAMEPLATE DATA

MFG Dayton
 MODEL 4HX94A
 TYPE Curve
 SIZE 1

SHEAVE DATA:
 DIA 1 1/2 SHAFT 7/8"
 BELTS (1) 4L-210

DATA ITEM	TEST 1	TEST 2	TEST 3
VOLTS	<u>118</u>		
AMPS	<u>9.2</u>		
BHP	<u>.61</u>		
RPM	<u>1197</u>		
SP -			
SP +			
TSP			
FILTER SP			
CFM TOTAL	<u>2294</u>		
CFM RA			
CFM OA			

FAN DESIGN DATA

CFM 2275 SP _____ RPM _____ BHP _____

ROOM	OPENING			FAC TOR	DESIGN		TEST 1		TEST 1		TEST 3	
	NO.	TYPE	SIZE		FPM	CFM	FPM	CFM	FPM	CFM	FPM	CFM
E9	AB	18x18	2.07	266		191	409	283	586			
E10	↓	↓	↓	266		178	381	277	573			
E11	↓	↓	↓	266		179	383	291	603			
E12	↓	↓	↓	266		166	355	257	532			
						2275	1528		2294			
							(67%)		(101%)			

REMARKS _____

CIRCO SYSTEM BALANCE, INC.

SB JOB NO. _____
 SECTION _____ PAGE _____
 DATE 2-6-01

FAN TEST SHEET

AREA SERVED Front Kitchen Area UNIT MAO-1

MOTOR NAMEPLATE DATA

MFG Emerson FR _____
 HP 1 V 115 FLA 14
 PH 1 SF 1725 RPM 1725

SHEAVE DATA
 DIA 1VP40 SHAFT 5/8
 ADJ %med FIXED _____

FAN NAMEPLATE DATA

MFG Phoenix
 MODEL D8801
 TYPE Evap
 SIZE _____

SHEAVE DATA:
 DIA 14"OD SHAFT 1 1/4"
 BELTS (1) 4L760

DATA ITEM	TEST 1	TEST 2	TEST 3
VOLTS	117	120	
AMPS	12.2	9.8	
BHP	.87	.70	
RPM	383	338	
SP -	/	/	
SP +	/	/	
TSP	/	/	
FILTER SP	/	/	
CFM TOTAL	4852	4248	
CFM RA	-	-	
CFM OA	-	-	

FAN DESIGN DATA

CFM 4350 SP _____ RPM _____ BHP _____

REMARKS: 4 1/4 x 13 1/2 x 4 sides .85 Factor .38

#1	#2		
1601	1555	1452	1351
1592	1622	1426	1407
1648	1607	1401	1337
1654	1490	1538	1269
<u>6495</u>	<u>6274</u>	<u>5817</u>	<u>5364</u>
2468	2384	2210	2038
<u>4852 cfm</u>		<u>4248</u>	
<u>112%</u>		<u>98%</u>	

CIRCO SYSTEM BALANCE, INC.

SB JOB NO. _____
 SECTION _____ PAGE _____
 DATE 2-5-01

FAN TEST SHEET

AREA SERVED Rear Kitchen Area UNIT MAV-2

MOTOR NAMEPLATE DATA

MFG Emerson FR _____
 HP 1/2 V 115 FLA. 7.8
 PH 1 SF 160 RPM 1725

SHEAVE DATA
 DIA 1/2 SHAFT 1/2"
 ADJ _____ % _____ FIXED _____

FAN NAMEPLATE DATA

MFG Phoenix
 MODEL DM 4800 B
 TYPE EVAL
 SIZE _____


SHEAVE DATA
 DIA 1 1/8" OD SHAFT _____
 BELTS (1) 42570

DATA ITEM	TEST 1	TEST 2	TEST 3
VOLTS	121	121	
AMPS	4.3	6.5	
BHP	.28	.42	
RPM	402	496	
SP -	/	/	
SP +	/	/	
TSP			
FILTER SP			
CFM TOTAL	1599	2183	
CFM RA	-	-	
CFM OA	-	-	


FAN DESIGN DATA

CFM 2275 SP _____ RPM _____ BHP _____

REMARKS



FRAMING DETAIL ADDENDUM



FRAMING SECTION

SCALE: 1" = 1'-0"

DCA **DARRYL CHINN ARCHITECTS**
 2812 J STREET #2
 SACRAMENTO, CA
 95815-4313
 OFF 916 446 1793
 FAX 916 446 2690

Jimboy's Restaurant
 ADDITION AND REMODEL
 1420 29th Street
 Sacramento, California 95816

January 29 2001

TOTAL P.02

MEMORANDUM

SACRAMENTO FIRE DEPARTMENT

TO: BUILDING DEPARTMENT

DATE: 3-14-01

FROM: Troy Malaspino
Fire Marshal

SUBJECT: FIRE SYSTEM INSPECTION

A final inspection of the newly installed fire system at:

1420 29th ST

Has been conducted by Inspector

C. Packer

On

2-13-01

00-02072-305
Permit Number

Square Footage

(3) Kitchen Grease
Type of Inspection


Jimboys Tacos

They system is acceptable by this department.

R. Woodman

By: Ross L. Woodman,
Fire Prevention Officer II


00 454
F.D. Reference Number



Just fell into place adjacent to each fan - even easier

Typ B4

MMB 2-6-01



This set of plans and specifications must be kept on the job at all times and it is unlawful to make any changes or alterations from the same without written permission from the Building Department. The approval of this plan and specification SHALL NOT be held to permit or approve the violation of any City Ordinance or State Law.