

① 172 J194-204 1/4

BUILDING DIVISION — BUILDING INSPECTOR'S REPORT CARD \$155.00

① R184 J250-251  
(new plot plans)

TYPE BUILDINGS

plus item 8-31-65  
① 179 J521

|                      |  |                               |                               |                      |  |
|----------------------|--|-------------------------------|-------------------------------|----------------------|--|
| PERMIT NO.<br>F-1038 |  | LOCATION 410 - N. 10th Street |                               | A-2                  |  |
| DATE<br>July 1-65    | PURPOSE<br>Const. off., display, & repair gar for  |                               |                               |                      |  |
| ZONE<br>M-2          | OWNER<br>Setro Inc. 56-Freenport Bl/lift-all for k |                               |                               |                      |  |
|                      | ARCH'T<br>George Muraki 60 /lift                   |                               |                               |                      |  |
|                      | CONT'R<br>John F. Otto 4330-24th St.               |                               |                               |                      |  |
| VAL. \$56,600.       | STORIES  | ROOMS                         | APTS.                         | SIZE<br>9820 sq. ft. |  |
| INSP.                | DATE   | BLDG. TYPE<br>V - no sur.     | OCCUPANCY GROUP<br>E-2<br>E-4 | PHONE (O) (C)        |  |
| FORM                 | 7-15-65  | Quint                         |                               |                      |  |
| JOIST                |  |                               |                               |                      |  |
| FRAME                | 9-3-65   | Quint                         |                               |                      |  |
| SHEET ROCK           | 9-3-65   | Quint                         |                               |                      |  |
| FINAL                | 11-20-65   | J. Barlow                     | ent. comm.                    |                      |  |



| DATE            | SPECIAL CONDITIONS OF WORK — REMARKS   |
|-----------------|--|
| 0-13-65         | Kt form - not ready <span style="float: right;">Court</span>   |
| 1-14-65         | Kt form - no approved plan <span style="float: right;">Court</span>  |
| 1-24-65         | OK set up barrels <span style="float: right;">Court</span>   |
| 2-27-65         | OK 1 pole <span style="float: right;">Court</span>   |
| 8-10-65         | OK plumb line <span style="float: right;">Court</span>   |
| 8-23-65         | OK roof nail <span style="float: right;">Court</span>  |
| 8-30-65         | Kt no fabrication report on glass tank <span style="float: right;">Court</span>  |
| 9-9-65          | OK tank <span style="float: right;">Hammers / Court</span>   |
| 9-17-65         | OK set up post. OK to move <span style="float: right;">50' dia</span>  |
| 10-7-65         | D. J. Rindel - planters not finished; address not on ledge; front driveway not installed; deck over parts dept. being used as storage with stairs <span style="float: right;">Hammers</span> |
| COMPLETE AND OK | INSPECTOR  |