

BUILDING DIVISION—BUILDING INSPECTOR'S REPORT CARD

TYPE BUILDINGS *R3-F30-44*

PERMIT NO. <i>B-37724</i>	LOCATION ^{<i>2150</i>} <i>2110</i> <i>Stockton Blvd. R4-F514-517</i>			
DATE <i>4-6-53</i>	PURPOSE <i>Erect one story monastery (Catholic)</i>			
ZONE	OWNER <i>Carmelite Monastery</i>			
	ARCH'T.			
	CONTR. <i>John H. Barden</i>			
VAL. <i>\$125,000.00</i>	STORIES	ROOMS	APTS.	SIZE
LIGHT SHAFTS	ELEVATOR SHAFTS			
VENT SHAFTS	BOILER ROOMS			
OWNER'S INSPECTOR	SPRINKLER SYSTEM			
LATH	GAS VENTS			
FIRE ESCAPES	CHIMNEYS			
STAND PIPES	SKYLIGHTS			

DATE	CONDITION OF WORK—REMARKS
4-14-53	Forms <i>MA Shumway</i>
4-16-53	Forms <i>MA Shumway</i>
8-22-53	<p>Final O.K.</p> <p>Fire stop between floor and earth @ each basement to be installed.</p>
	<p>COMPLETE AND O. K.</p> <p style="text-align: right;">INSPECTOR</p>