



CITY OF SACRAMENTO

19

CITY MANAGER'S OFFICE
RECEIVED
4 1981

DIVISION OF WATER AND SEWERS
927 - 10TH ST.
SUITE #201
SACRAMENTO, CALIFORNIA 95814
TELEPHONE (916) 449-5271

HARRY G. BEHRENS
MANAGER
ROBERT W. JOHNSTON
ASSISTANT MANAGER

March 4, 1981

City Council
Sacramento, California

Honorable Members in Session:

SUBJECT: Approval of Plans and Specifications for the Construction of Retaining Walls at the Sacramento River Water Treatment Plant

SUMMARY

The Division of Water and Sewers has prepared plans and specifications for the subject project. Copy of said plans and specifications has been forwarded to the City Clerk and approval is recommended.

BACKGROUND

The Sacramento River Water Treatment Plant has been in operation since the 1920's. In 1978, two additional high-lift pumps were installed as part of the plant expansion to provide additional capacity and flexibility for pumping filtered water. The pumps were located in a recessed area above the old reservoir. Because the soil is very sandy, retaining walls are necessary to prevent the soil from sliding into the pumping area.

FINANCIAL DATA

This project is in the Capital Improvements Program as part of the Sacramento River Water Treatment Plant Expansion. Estimated construction cost is \$12,000.00 Adequate funds are available to cover the estimated costs, 4-13-3020-1501-4820.

RECOMMENDATION

It is recommended that the plans and specifications be approved and that bids be received on March 31, 1981.

APPROVED
BY THE CITY COUNCIL

MAR 10 1981

OFFICE OF THE
CITY CLERK

Respectfully submitted,

Harry G. Behrens, Manager

R. H. Parker, City Engineer

Recommendation approved:

Walter J. Slize, City Manager

March 10, 1981
District #1