

CITY OF SACRAMENTO
1231 I Street, Sacramento, CA 95814

Permit No: 9911341
Insp Area: 4

Site Address: 3929 DRY CREEK RD SAC
Parcel No. 251-0024-006

Sub-Type: RES
Housing (Y/N): Y

CONTRACTOR
PAUL DENNIS INC. DBA P.H.D. CONSTRUCTION
PO BOX 1658
SHINGO SPRINGS CA 95682

OWNER
SACRAMENTO CA
95821

ARCHITECT
GEORGE CALE

Nature of Work: REPAIRS PER HOUSING CHECKLIST

CONSTRUCTION LENDING AGENCY: I hereby affirm under penalty of perjury that there is a construction lending agency for the performance of the work for which this permit is issued (Sec. 3097, Civ. C.)

Lender's Name _____ Lender's Address _____

LICENSED CONTRACTORS DECLARATION: I hereby affirm under penalty of perjury that I am licensed under provisions of Chapter 9 (commencing with section 7000) of Division 3 of the Business and Professions Code and my license is in full force and effect.

X License Class _____ License Number 92310-0001 Date 2-21-00 Contractor Signature Paul Dennis

OWNER-BUILDER DECLARATION: I hereby affirm under penalty of perjury that I am exempt from the contractors License Law for the following reason (Sec. 7031.5, Business and Professions Code: any city or county which requires a permit to construct, alter, improve, demolish, or repair any structure, prior to its issuance, also requires the applicant for such permit to file a signed statement that he or she is licensed pursuant to the provisions of the Contractors License Law (Chapter 9 (commencing with Section 7000) of Division 3 of the Business and Professions Code) or that he or she is exempt therefrom and the basis for the alleged exemption. Any violation of Section 7031.5 by any applicant for a permit subjects the applicant to a civil penalty of not more than five hundred dollars (\$500.00);

I, _____, as a owner of the property, or my employees with wages as their sole compensation, will do the work, and the structure is not intended or offered for sale (Sec. 7044, Business and Professional Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who does such work himself or herself or through his/her own employees, provided that such improvements are not intended or offered for sale. If, however, the building or improvement is sold within one year of completion, the owner-builder will have the burden of proving that he/she did not build or improve for the purpose of sale.)

I, _____, as owner of the property, am exclusively contracting with licensed contractors to construct the project (Sec. 7044, Business and Professions Code). The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who contracts for such projects with a contractor(s) licensed pursuant to the Contractors License Law).

I am exempt under Sec. _____ B & PC for this reason: _____
Date _____ Owner Signature _____

IN ISSUING THIS BUILDING PERMIT, the applicant represents, and the city relies on the representation of the applicant, that the applicant verified all measurements and locations shown on the application or accompanying drawings and that the improvement to be constructed does not violate any law or private agreement relating to permissible or prohibited locations for such improvements. This building permit does not authorize any illegal location of any improvement or the violation of any private agreement relating to location of improvements.

I certify that I have read this application and state that all information is correct. I agree to comply with all city and county ordinances and state laws relating to building construction and hereby authorize representative(s) of this city to enter upon the above-mentioned property for inspection purposes.

X Date 2-21-00 Applicant/Agent Signature Paul Dennis

WORKER'S COMPENSATION DECLARATION: I hereby affirm under penalty of perjury one of the following declarations:
I have and will maintain a certificate of consent to self-insure for workers' compensation as provided for by Section 3700 of the Labor Code, for the performance of work for which the permit is issued.

I have and will maintain workers' compensation insurance, as required by Section 3700 of the Labor Code, for the performance of the work for which this permit is issued. My workers' compensation insurance carrier and policy number are:

Carrier _____ Policy Number _____ Exp Date _____

(This section need not be completed if the permit is for \$100 or less) I certify that in the performance of the work for which this permit is issued, I shall not employ any person in any manner so as to become subject to the workers' compensation laws of California and agree that if I should become subject to the workers' compensation provisions of Section 3700 of the Labor Code, I shall forthwith comply with those provisions.

X Date 2-21-00 Applicant Signature Paul Dennis

WARNING: FAILURE TO SECURE WORKER'S COMPENSATION COVERAGE IS UNLAWFUL AND SHALL SUBJECT AN EMPLOYER TO CRIMINAL PENALTIES AND CIVIL FINES UP TO ONE HUNDRED THOUSAND DOLLARS (\$100,000) IN ADDITION TO THE COST OF COMPENSATION, DAMAGES AS PROVIDED FOR IN SECTION 3706 OF THE LABOR CODE, INTEREST AND ATTORNEY'S FEE.

HOUSING CASE SUMMARY -- Case # HSG 10225
as of 02/16/1999

99 11341H

Cond: B02

Dangerous to human life or detrimental to health.

49.04.402(C)

Entry: 2/16/99 By: PWM Action: NOTE SEWAGE
OVERFLOW A HEALTH HAZARD

Cond: B14

Flooring or floor supports of insufficient size to carry
imposed loads with safety. 49.10.1003(3)

Entry: 2/16/99 By: PWM Action: NOTE STAIRS
LEADING FROM HOUSE TO GARAGE ARE UNSAFE AND OF ILLEGAL
DIMENSION

Cond: B20

Building or portion thereof, device, apparatus, equipment,
combustible waste, or vegetation which is such a condition
as to be a fire hazard. 49.10.1009

Entry: 2/16/99 By: PWM Action: NOTE WINDOW
BARS OVER BEDROOM WINDOWS THAT DO NOT HAVE SAFETY RELEASES
MUST BE REMOVED.

Cond: B25

Inadequate fire protection and equipment. 49.10.1014

Entry: 2/16/99 By: PWM Action: NOTE SMOKE
DETECTORS ARE INOPERABLE.

Cond: E02

Exposed conductors, wire joints or energized equipment.
49.07.702

Entry: 2/16/99 By: PWM Action: NOTE
EXPOSED CONDUCTORS AT GARAGE CEILING LIGHT FIXTURE AND
INTERIOR WALL OUTLETS

Cond: E03

Faulty equipment or wiring presenting a hazard to person or
property. 49.10.1005

Entry: 2/16/99 By: PWM Action: NOTE TENANT
STATES SEVERAL WALL OUTLETS ARE ONLY WORKING SPORADICALLY.