

BUILDING DIVISION—BUILDING INSPECTOR'S REPORT CARD

TYPE BUILDINGS

PERMIT No. <i>A-1575</i>	LOCATION <i>1131-10th St.</i>			
DATE <i>4/19/34</i>	PURPOSE <i>Gen. Alterations & Repairs for Store - Warner Bros</i>			
ZONE <i>Gen. Com.</i>	OWNER <i>Warner Bros</i>			
	ARCH'T <i>Chas Vinger</i>			
	CONT'R <i>Chas Vinger</i>			
VAL. <i>1000⁰⁰</i>	STORIES	ROOMS	APTS.	SIZE
Light Shafts		Elevator Shafts		
Vent Shafts		Boiler Rooms		
Owner's Inspector		Sprinkler System		
Lath		Gas Vents		
Fire Escapes		Chimneys		
Stand Pipes		Skylights		

DATE	CONDITION OF WORK—REMARKS
4/24/34	Niche Framed in for access in partition between 2 stores - In Restaurant OK. M. Campbell
	300 hrs. Plasterboard both sides of partition
	<p data-bbox="319 831 468 878">COMPLETE AND O. K.</p> <p data-bbox="1117 857 1276 878">INSPECTOR</p>