

Checklist

99-05391

6047-0620-7407 ©1997, Moore® All Rights Reserved - 0305m

0177

PERMIT NO.
[]

CITY OF SACRAMENTO
1231 I ST.
HOUSING & DANGEROUS BUILDINGS DIVISION

AREA NO.
[]

CORRECTION NOTICE

WHEN CORRECTIONS HAVE BEEN MADE CALL 264-5850 OR 264-5404 FOR INSPECTIONS

JOB LOCATION 2530 Clay "c"

INSPECTION REQUESTED _____

THE UNDERSIGNED BUILDING PLUMBING MECHANICAL ELECTRICAL
INSPECTOR THIS DAY INSPECTED THIS STRUCTURE FOR THE REQUESTED INSPECTION AND FOUND THE FOLLOWING VIOLATIONS OF CITY AND/OR STATE LAWS GOVERNING SAME:

CLARK WITTETZ

PG 810 1037

Repair Sub panel & Sewer pit
To Code provide all Bond's etc
Leak in plumbing through roof
Provide Vapor Barrier @ Floor
Weather strip front entry door
Repair Roof, Construct 1/2 wall
Between Gar & LL,

INSPECTOR _____

DATE 1/1