

R 246 + 199-366

BUILDING DIVISION — BUILDING INSPECTOR'S REPORT CARD \$3,226.50

Parcel #10 Chinatown TYPE BUILDINGS
Area "Old City"

PERMIT NO. H-291	CERT. R 342 F16		
DATE Feb. 18-71	PURPOSE	Const. 13-story Apartment Building	
ZONE C-3	OWNER	Wong, Kuong, Hur, Wen, Sun Assoc. 920-T St.	
	ARCH'T	McGuire & Eatough/1st & 2nd office area	
	CONTR	Campbell Const. Co. 2120 - 20th Street	

VAL. \$3,109,000.	STORIES 13	ROOMS	APTS. 187	171,000 sq. ft.	SIZE
-------------------	---------------	-------	--------------	-----------------	------

INSP.	DATE	BLDG. TYPE I-1	OCCUPANCY GROUP & H	PHONE (O) (C) 452-5371
-------	------	-------------------	------------------------	---------------------------

FORM

JOIST

FRAME 7-5-73 Calloway

SHEET ROCK 7-12-73 Calloway 7-13 13 Calloway Const. sent 62-26-72 Jim Lee

FINAL

DATE	SPECIAL CONDITIONS OF WORK — REMARKS
8-29-72	OK sp. 3rd floor Court
11-13-72	$\left. \begin{array}{l} \text{FF - final} \\ \text{OR - final} \end{array} \right\} \begin{array}{l} 1. \text{ No Landscaping} \\ 2. \text{ Stairways (interior) over } 3' \text{ max. } \end{array}$
11-22-72	OK final 9th, 10th, 11th & 12th Flr. Calloway
11-27-72	OK final 14th flr. to the 14th Flr. Calloway
12-6-72	At 9th fl: they've installed 2 layers of $\frac{5}{8}$ " sp over bottom of shaft in hallway in Calloway
12-11-72	Beam on 2nd flr. has not been fire-protected Calloway
12-18-72	Pt. Belmont does not have fire protection on it Calloway
12-23-72	OK Beam 14 Calloway
COMPLETE AND OK	INSPECTOR