

**BUILDING DIVISION - BUILDING INSPECTOR'S REPORT CARD**

**TYPE BUILDINGS**

PERMIT NO. <i>No charge</i>	LOCATION	PHONES
DATE <i>007 23</i> <i>1931</i>	PURPOSE <i>Make repairs to front steps &amp; Dry Rot &amp; Termites</i>	
ZONE <i>Multiple Family</i>	OWNER <i>CORNELIA FINOS</i>	
	ARCH'T	
	CONT-R <i>OWNER</i>	

*915-29<sup>th</sup> St*

VAL. <i>3000</i>	STORIES <i>1</i>	ROOMS	APTS.	SIZE
------------------	------------------	-------	-------	------

Light Shafts		Elevator Shafts	
Vent Shafts		Boiler Rooms	
Owner's Inspector		Sprinkler System	
Lath		Gas Vents	
Fire Escapes		Chimneys	
Stand Pipes		Skylights	

DATE

CONDITION OF WORK-REMARKS

10/23/31

Gave Owner this No Chaise Permit & make repairs to front steps. Noted his bottom 17 step buttresses would have to be cut off up to a height 3" above grade. Originally built a foot below grade with earth fill against wood work. Said wood rotted and affected by Termites. Now being treated by Termites Control Operator.

RM Campbell

COMPLETE  
AND O.K.

INSPECTOR