

BUILDING DIVISION—BUILDING INSPECTOR'S REPORT CARD

TYPE VII BUILDINGS LOT 223 H4K #33

PERMIT NO. 5673	LOCATION 223 MK 33	720-47TH ST.	
DATE Dec. 14, 1939	PURPOSE 2-Story 2-Family Frame Stucco Co. Fin v Bath each D.H.G. Plans	(4) ROOMS	APTS. (2)
ZONE 2-Family	OWNER M.B. Williams	PHONE	
	ARCH'T <i>[Signature]</i>		
	CONT'R <i>[Signature]</i>		
	VAL. <i>[Signature]</i>	STORIES 1.	SIZE 24x42-21

FOUNDATION	STORY	BSMT	1	2	3	ROOF		
Ex Wall	Joints						Chimneys	Cement Tests
	Beams and Girders						Fire Place	
Int Wall	Studs and Columns						Gas Water Heater	
	Bridging Fire Stops						Heater Closet	
Piers	Fire Escape Stand Pipes						Furnace	Window Courts
	Metal Lath						Boiler Room	
	Stairs						Elevator Shaft	



DATE	CONDITION OF WORK—REMARKS
12/16/29	1 st /NSP Footings for Ext Walls ^{OK} A.W. Campbell
12/17/29	1 st /NSP Forms " " over also pour and finishing base Footings OK A.W. Campbell
1/8/30	2 nd /NSP Frame in place OK A.W. Campbell
1/8/30	3 rd /NSP Est. base 2 ft. base 18 gings were neglected directly to studs over Notified Contractor to pour base. Return 2 nd A.W. Campbell
1/27/30	B Imp Int Lath OK R.H. Runtz Also hidden beams to 20 inches. OK Contractor finally Notified Contractor for place chimney top log, raised same OK A.W.C. " " to install vents under floor joists. Did as later.
3/20/30	4 th /NSP. House + Garage Finally Completed A.W. Campbell
	ISSUED CERTIFICATE OF OCCUPANCY #5673
	Street Cleaned up. OK. A.W. Campbell
3/26/30	COMPLETED AND O.K. <u>Alden W. Campbell</u> INSPECTOR

