

BUILDING DIVISION—BUILDING INSPECTOR'S REPORT CARD

TYPE VII BUILDINGS

PERMIT NO. 5435	LOCATION 1125 K St		
DATE 10/25/49	PURPOSE Add 2nd story	ROOMS	APTS.
ZONE	OWNER J. H. ...	PHONE	
	ARCH'T		
	CONT'R		
	VAL.	STORIES	SIZE

FOUNDATION	STORY	BSMT	1	2	3	ROOF		
EX WALL	Joints						Chimneys	Cement Tests
	Beams and Girders						Fire Place	
Int Wall	Studs and Columns						Gas Water Heater	
	Bridging Fire Stops						Heater Closet	
Piers	Fire Escape Stand Pipes						Furnace	Window Courts
	Metal Lath						Boiler Room	
	Stairs						Elevator Shaft	

addition

General Commercial Zone

DATE	CONDITION OF WORK-REMARKS
10/24/29	1 st /NSP Bracke Fastening for Bracke Addition to front of Bldg for Store ^{AW Campbell}
10/29/29	1 st /NSP Owner moved Stairs 2 nd Story East ^{AW Campbell}
10/30/29	Owner changed from Wood ^{AW Campbell} ^{OK} ^{AW Campbell}
11/7/29	T. WAI HING (Owner) agreed to foreproof walls against ledge for private garage with metal lath & plaster ^{AW Campbell}
11/27/29	3 rd /NSP Metal Lath on interior of walls of 2 nd story ^{AW Campbell}
11/29/29	2 nd /NSP Plaster on 2 nd story ^{AW Campbell}
12/6/29	3 rd /NSP INT LATH Metal Lath on interior of walls for Store only ^{AW Campbell}
12/30/29	2 nd /NSP Frame for 2 nd Story Stairs & Rupture ^{AW Campbell}
3/26/30	3 rd /NSP INT to the 2 nd Story Metal Lath Support of Stairs ^{AW Campbell}
COMPLETED AND O.K.	INSPECTOR