

A-59

BUILDING DIVISION—BUILDING INSPECTOR'S REPORT CARD

F 562 -

TYPE BUILDINGS \$3.00

PERMIT NO. D-2956	LOCATION	2785 Marty Way		A-2
DATE Aug. 17, 59	PURPOSE	Repair termite damage to dwlg.		
ZONE	OWNER	Dunnigan Yates & Stone		
	ARCH'T			
	CONT'R	Valley Termite 1617-18th St. GI 8-1882		
VAL. \$400.	STORIES	ROOMS	APTS.	SIZE
INSP.	DATE	INSPECTOR		
FORM				
JOIST	8-11-59	Shumway		
FRAME		*		
LATH	9-16-59	Shumway		
FINAL				

DATE	SPECIAL CONDITIONS OF WORK—REMARKS
* 9-10-58	checked work ok but not ready M.A. Shuman
9-15-59	Paint Job. Too much wood showing suggest lin glazing. Followup.
10-7-59	P.T. Crack in plaster not fixed
	<div data-bbox="301 839 427 890" data-label="Text">COMPLETE AND OK</div> <div data-bbox="1162 865 1295 896" data-label="Text">INSPECTOR</div>