CITY OF SACRAMENTO

1231 I Street, Sacramento, CA 95814

Permit No: 0414726
Insp Area: 4
Thos Bros: 298A1

Site Address: 1500 RIVER PARK DR SAC St: #226
Parcel No: 277-0287-002 STE 226

Sub-Type: REM
Housing (Y/N): N

CONTRACTOR
BROWNING CONSTRUCTION INC
9050 RANCHVIEW CT
SACRAMENTO CA 95624

OWNER
SCHOOLS FEDERAL CREDIT UNION
P O BOX 526001
SACRAMENTO, CA 95852

ARCHITECT
NIELSEN & ASSOCIATES
550 HOWE AVE
SACRAMENTO CA 95825

Nature of Work: INTERIOR REMODEL FOR STE 226

CONSTRUCTION LENDING AGENCY : I hereby affirm under penalty of perjury that there is a construction lending agency for the performance of the work for which this permit is issued (Sec. 3097, Civ. C).

Lender's Name_____ Lender'sAddress_____

LICENSED CONTRACTORS DECLARATION: I hereby affirm under penalty of perjury that I am licensed under provisions of Chapter 9 (commencing with section 7000) of Division 3 of the Business and Professions Code and my license is in full force and effect.

License Class B License Number 461321 Date 9/8/04 Contractor Signature [signature]

OWNER-BUILDER DECLARATION: I hereby affirm under penalty of perjury that I am exempt from the contractors License Law ~~for the following~~ reason (Sec. 7031.5, Business and Professions Code; any city or county which requires a permit to construct, alter, improve, demolish, or repair any structure, prior to its issuance, also requires the applicant for such permit to file a signed statement that he or she is licensed pursuant to the provisions of the Contractors License Law (Chapter 9 (commencing with Section 7000) of Division 8 of the Business and Professions Code) or that he or she is exempt therefrom and the basis for the alleged exemption. Any violation of Section 7031.5 by any applicant for a permit subjects the applicant to a civil penalty of not more than five hundred dollars ($500.00);

_____ I, as a owner of the property, or my employees with wages as their sole compensation, will do the work, and the structure is not intended or offered for sale (Sec. 7044, Business and Professional Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who does such work himself or herself or through his/her own employees, provided that such improvements are not intended or offered for sale. If, however, the building or improvement is sold within one year of completion, the owner-builder will have the burden of proving that he/she did not build or improve for the purpose of sale.)

_____ I, as owner of the property, am exclusively contracting with licensed contractors to construct the project (Sec. 7044, Business and Professions Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who contracts for such projects with a contractor(s) licensed pursuant to the Contractors License Law).

_____ I am exempt under Sec._____ B & PC for this reason:_____

Date_____ Owner Signature_____

PAID
CITY OF SACRAMENTO
SEP 08 2004
PERMIT CENTER

IN ISSUING THIS BUILDING PERMIT, the applicant represents, and the city relies on the representation of the applicant, that the applicant verified all measurements and locations shown on the application or accompanying drawings and that the improvement to be constructed does not violate any law or private agreement relating to permissible or prohibited locations for such improvements. This building permit does not authorize any illegal location of any improvement or the violation of any private agreement relating to location of improvements.

I certify that I have read this application and state that all information is correct. I agree to comply with all city and county ordinances and state laws relating to building construction and herby authorize representative(s) of this city to enter upon the abovementioned property for inspection purposes.

Date 9/8/04 Applicant/Agent Signature [signature]

WORKER'S COMPENSATION DECLARATION: I hereby affirm under penalty of perjury one of the following declarations:
_____ I have and will maintain a certificate of consent to self-insure for workers' compensation as provided for by Section 3700 of the Labor Code, for the performance of work for which the permit is issued.

DB I have and will maintain workers' compensation insurance, as required by Section 3700 of the Labor Code, for the performance of the work for which this permit is issued. My workers' compensation insurance carrier and policy number are:

Carrier STATE FUND Policy Number 713016444 Exp Date 10/01/2004

_____ (This section need not be completed if the permit is for $100 or less) I certify that in the performance of the work for which this permit is issued, I shall not employ any person in any manner so as to become subject to the workers' compensation laws of California and agree that if I should become subject to the workers' compensation provisions of Section 3700 of the Labor Code, I shall forthwith comply with those provisions.

Date 9/8/04 Applicant Signature [signature]

WARNING: FAILURE TO SECURE WORKER'S COMPENSATION COVERAGE IS UNLAWFUL AND ~~SHALL~~ SUBJECT AN EMPLOYER TO CRIMINAL PENALTIES AND CIVIL FINES UP TO ONE HUNDRED THOUSAND DOLLARS ($100,000) IN ADDITION TO THE COST OF COMPENSATION, DAMAGES AS PROVIDED FOR IN SECTION 3706 OF THE LABOR CODE, INTEREST AND ATTORNEY'S FEE.

THIS PERMIT SHALL EXPIRE BY LIMITATION IF WORK IS NOT COMMENCED WITHIN 180 DAYS.

1485 RESPONSE
2ND FLOOR

INDOOR ENVIRONMENTAL SERVICES

AIR BALANCE REPORT

1485 Response
Job Name: Browning Const. 5-226 Job Num 20-0210 Date 9/29/04

Tech: JESS Section: Page

UNIT	OUTLET	NO.	OPENING TYPE	SIZE(in)	FACTOR	DESIGN FPM	DESIGN CFM	TEST 1 FPM	TEST 1 CFM	TEST 2 FPM	TEST 2 CFM	TEST 3 FPM	TEST 3 CFM
	1		CD	10 ϕ	1.0		125		95		113		
	2		↓	6" ϕ	↓		125		130		110		
	3		↓	10" ϕ	↓		305		330		308		
							555				531		
	1		CD	12" ϕ			310		240		202		
	2		↓	10" ϕ			310		100		201		
	3		↓	12" ϕ			400		400		270		
	4		↓	8" ϕ			195		140		125		
	5		↓	10" ϕ			235		195		160		
*	6		↓	10" ϕ			275		140		182		
	7		↓	10" ϕ			275		160		181		
							2000		1375		1321		

REMARKS #6 NO DAMPER in DUCT closed OFF FACE DEFLECTORS
#1 (E) DAMPER will NOT CLOSE ANY FURTHER, CLOSED OFF THROUGH FACE DEFLECTORS.