

BUILDING DIVISION-BUILDING INSPECTOR'S REPORT CARD

TYPE BUILDINGS

PERMIT No. <i>A-1878</i>	LOCATION <i>2101-9th Street</i>			
DATE <i>7/31/34</i>	PURPOSE <i>Make gen. repairs to PHONES, E.</i>			
ZONE <i>Wd. Jan.</i>	OWNER <i>Garrick Mrs W-A</i>			
	ARCH'T <i>Louis Garrison</i>			
	CONT'R <i>Louis Garrison</i>			
VAL. <i>2000</i>	STORIES	ROOMS	APTS.	SIZE

Light Shafts		Elevator Shafts	
Vent Shafts		Boiler Rooms	
Owner's Inspector		Sprinkler System	
Lath		Gas Vents	
Fire Escapes		Chimneys	
Stand Pipes		Skylights	

DATE	CONDITION OF WORK-REMARKS
7/31/34	Made Inspection of Bridge Foundation
	Found condition of Stry. Deteriorated
	Notified Engineer for repairs under contract of Rep.
	Supported by mudsills should be cut off
	and concrete of bridge piers built on ground
	A. H. Campbell
COMPLETE AND O. K.	INSPECTOR