

BUILDING DIVISION-BUILDING INSPECTOR'S REPORT CARD

TYPE BUILDINGS

PERMIT NO. <i>8424</i>	LOCATION <i>12th Plm.</i>			
DATE <i>8/17/31</i>	PURPOSE <i>Gen. Rep. Improvement</i>			
ZONE <i>Model Farm</i>	OWNER <i>Julian Miles</i>			
	ARCH'T <i>Julian Miles</i>			
	CONT-R <i>Owner</i>			
VAL. <i>100</i>	STORIES	ROOMS	APTS.	SIZE

Light Shafts		Elevator Shafts	
Vent Shafts		Boiler Rooms	
Owner's Inspector		Sprinkler System	
Lath		Gas Vents	
Fire Escapes		Chimneys	
Stand Pipes		Skylights	

DATE	CONDITION OF WORK-REMARKS
8/17/31	Made Partial Insp of new floor & joists in basement. Notified Owner to provide 3 Vents on each side of house below floor and to bridge floor joists A.W. Campbell
8/20/31	2 ND Insp. Frame for " " " " A.W. Campbell Note. Basement not to be used for living purposes as Ceiling Height is only 7 ft. - State Housing Law requires 8 ft.
	<div style="display: flex; justify-content: space-between;"> COMPLETE AND O.K. INSPECTOR </div>