

## BUILDING DIVISION—BUILDING INSPECTOR'S REPORT CARD

## TYPE BUILDINGS

D-21-12

PERMIT NO. <i>B-24115</i>	LOCATION <i>604-13 street</i>			
DATE <i>12-17-48</i>	PURPOSE <i>Remodal for apt.</i>			
ZONE	OWNER <i>C.E. Johns</i>			
	ARCH'T.			
	CONT'R. <i>Owner</i>			
VAL. <i>\$4000</i>	STORIES	ROOMS	APTS.	SIZE
LIGHT SHAFTS		ELEVATOR SHAFTS		
VENT SHAFTS		BOILER ROOMS		
OWNER'S INSPECTOR		SPRINKLER SYSTEM		
LATH		GAS VENTS		
FIRE ESCAPES		CHIMNEYS		
STAND PIPES		SKYLIGHTS		

DATE	CONDITION OF WORK-REMARKS
2/15/19	No Form Insp. Called for Q. E. Puckius
2/16/19	Form Insp. (Stairs too narrow, rise too high, winders wrong, no storage allowed under stairs) Q. E. Puckius
	COMPLETE AND O. K. <span style="float: right;">INSPECTOR</span>