

BUILDING DIVISION—BUILDING INSPECTOR'S REPORT CARD

TYPE VII BUILDINGS

PERMIT NO. 7011	LOCATION 1570 S. St		
DATE 9/25/20	PURPOSE Brick over Roof	ROOMS	APTS.
ZONE	OWNER Allen (ALLEN GARAGE)	PHONE	
	ARCH'T		
	CONT'R Brick Roofing Co		
	VAL. 1400.00	STORIES 2	SIZE

FOUNDATION	STORY	BSMT	1	2	3	ROOF	Chimneys		Cement Tests
Ex Wall	Joints								
	Beams and Girders						Fire Place		
Int Wall	Studs and Columns						Gas Water Heater		
	Bridging Fire Stops						Heater Closet		
Piers	Fire Escape Stand Pipes						Furnace		Window Courts
	Metal Lath						Boiler Room		
	Stairs						Elevator Shaft		

DATE	CONDITION OF WORK--REMARKS
9/25/30	<p>Made Partial Insp. of Repairs to Roof. Found Contractor had Kettle Tar Chunks and gravel in alley. Notified Contractor to take out Street Deposit for same. Contractor did so. Contractor removed all old gravel from roof now applying a flood coat of Asph/Flt. pre-puratory to covering same with new gravel.</p>
	<p>COMPLETED AND O.K.</p> <p style="text-align: right;">INSPECTOR</p>