



25

RECEIVED  
FEB 17 1988

DEPARTMENT OF  
PUBLIC WORKS

ENGINEERING DIVISION

THOMAS M. FINLEY  
ENGINEERING DIVISION MANAGER

CITY OF SACRAMENTO  
CALIFORNIA

927 TENTH STREET  
ROOM 200  
SACRAMENTO, CA  
95814-2705

916-449-8220

CONSTRUCTION SECTION  
640 BERCUT DRIVE  
SUITE B  
SACRAMENTO, CA  
95814-0131

916-449-5282

**APPROVED**  
BY THE CITY COUNCIL

FEB 23 1988

OFFICE OF THE  
CITY CLERK

February 23, 1988

City Council  
Sacramento, California

Honorable Members in Session:

**SUBJECT:** Sodium Hypochlorite/Sodium Bisulfite Storage and Feed Facility at  
Combined Wastewater Treatment Plant (PN:WA76) - Approval of  
Change Orders 2 and 3

SUMMARY

Kaweah Construction Company, Visalia, Ca., is the general contractor on the subject project. Approval of Change Orders 2 and 3 for necessary field changes is recommended.

BACKGROUND

The existing system for disinfection/dechlorination of wastewater at the combined wastewater treatment plant at South Land Park Drive and Fruitridge Road uses chlorine gas and sodium dioxide gas. Construction of this project will substitute sodium hypochlorite/sodium bisulfite and eliminate potential hazards associated with the use of the chemical gases. Change Order 2 provides for the relocation of a drain line and electrical conduit, required because underground conditions were found to be different than shown on the original plans and specifications. Change Order 3 provides for the welding of underground chlorine line connections required to meet the Chlorine Institute Standards.

FINANCIAL

Change Order 2 in the amount of \$10,484.72 and Change Order 3 in the amount of \$2,032.00 raise the total contract amount from \$306,319.05 to \$318,835.77. Funds currently budgeted to this project (737-500-WA76-4820; 425-500-WA76-4820) are sufficient to cover these change orders.

City Council  
Sodium Hypochlorite/Sodium Bisulfite Storage and Feed Facility at Combined  
Wastewater Treatment Plant (PN:WA76)  
February 23, 1988  
Page 2

RECOMMENDATION

It is recommended that the City Council approve Change Order 2 in the amount of \$10,484.72 and Change Order 3 in the amount of \$2,032.00.


Respectfully submitted,




THOMAS M. FINLEY  
Engineering Division Manager

Recommendation Approved:

Approved:



for: WALTER J. SLIPE  
City Manager



MELVIN H. JOHNSON  
Director of Public Works

FB:mw  
CE1-78  
02.1088

February 23, 1988  
District No. 4

051088  
CEI-10  
LXIM

OTASICE NO 0  
EODIADA 03 1080

QIA W80900  
MVCES Y 0188

OTASICE NO 0  
EODIADA 03 1080

RECOMMENDATION ADDRESS

ADDRESS

RECOMMENDATION ADDRESS  
ADDRESS OF OFFICE

RECOMMENDATION ADDRESS

RECOMMENDATION ADDRESS  
RECOMMENDATION ADDRESS

RECOMMENDATION ADDRESS

RECOMMENDATION ADDRESS  
RECOMMENDATION ADDRESS  
RECOMMENDATION ADDRESS  
RECOMMENDATION ADDRESS