

BUILDING DIVISION—BUILDING INSPECTOR'S REPORT CARD

TYPE VII BUILDINGS

PERMIT NO. <i>No Charge</i>	LOCATION <i>1-Story Frame Dwlg - 1120-33<sup>rd</sup> ST</i>		
DATE <i>8/10/30</i>	PURPOSE <i>MAKE REPAIRS TO FRONT STEPS</i>	ROOMS	APTS.
ZONE <i>Multiple Family</i>	OWNER <i>BERT DUFRENE</i>	PHONE	
	ARCH'T		
	CONT'R <i>OWNER</i>		
	VAL. <i>25<sup>00</sup></i>	STORIES <i>1</i>	SIZE

FOUNDATION	STORY	BSMT	1	2	3	ROOF		
Ex Wall	Jolts						Chimneys	Cement Tests
	Beams and Girders						Fire Place	
Int Wall	Studs and Columns						Gas Water Heater	
	Bridging Fire Stops						Heater Closet	
Piers	Fire Escape Stand Pipes						Furnace	Window Courts
	Metal Lath						Boller Room	
	Stairs						Elevator Shaft	

DATE	CONDITION OF WORK—REMARKS
3/10/52	<p data-bbox="273 202 1239 326">Gave No Charge Permit to Owner repairing front steps. Found Timbers affected by Termites.</p> <p data-bbox="273 326 1260 533">Took sample of wood " to office to send to Termite Commission. Told him to take out all wood affected and replace with new.</p> <p data-bbox="798 512 1162 595">A. J. Campbell</p>
	<p data-bbox="329 839 482 885">COMPLETED AND O.K.</p> <p data-bbox="1113 865 1253 885">INSPECTOR</p>