

Q181 4178

BUILDING DIVISION — BUILDING INSPECTOR'S REPORT CARD

\$10.00

TYPE BUILDINGS

PERMIT NO. F-2346	LOCATION 2555 - 52nd Street		A-1
DATE Nov 18-65	PURPOSE Make termite repairs to dwelling		
ZONE R-1	OWNER Mr. Pither same		
	ARCH'T		
	CONTR Midstate Termite Box 8827		665-2281
VAL \$900.	STORIES	ROOMS	APTS. SIZE
INSP.	DATE	BLDG. TYPE	OCCUPANCY GROUP PHONE (O) (C)
FORM			
JOIST			
FRAME SHEET ROCK	12-6-65	Corbuto	
FINAL	1-30-67	Calloway	ent

DATE	SPECIAL CONDITIONS OF WORK — REMARKS
12-1-65	Pt Frame - Flack wall incorrect No steel in block foundation (postings) Chapin
12-14-65	Pt Frame - Wood to earth contact. Foot brack girdle joints not supported properly. Pier posts not nailed many times Chapin
	COMPLETE AND OK INSPECTOR