CITY OF SACRAMENTO

1231 I Street, Sacramento, CA 95814

Permit No: 0510001
Insp Area: 1
Thos Bros:
Sub-Type: TI
Housing (Y/N): N

Site Address: 1415 L ST SAC St: 890
Parcel No: 006-0116-009 SUITE # 890

CONTRACTOR
RUDOLPH AND SLETTEN INC
1504 EUREKA RD SUITE 200
ROSEVILLE CA 95661

OWNER
ALLEN DOWNTOWN SACRAMENTO
6005 HIDDEN VALLEY RD
CARLSBAD, CA 92009

ARCHITECT
TECHSPACE
777 CAMPUS COMMONS DR #200
SACRAMENTO CA 95825

Nature of Work: TI FOR SHELL OFFICE SPACE

CONSTRUCTION LENDING AGENCY : I hereby affirm under penalty of perjury that there is a construction lending agency for the performance of the work for which this permit is issued (Sec. 3097, Civ. C).

Lender's Name_____ Lender'sAddress_____

LICENSED CONTRACTORS DECLARATION: I hereby affirm under penalty of perjury that I am licensed under provisions of Chapter 9 (commencing with section 7000) of Division 3 of the Business and Professions Code and my license is in full force and effect.

License Class B License Number 198069 Date 8-16-05 Contractor Signature_____

OWNER-BUILDER DECLARATION: I hereby affirm under penalty of perjury that I am exempt from the contractors License Law for the following reason (Sec. 7031.5, Business and Professions Code; any city or county which requires a permit to construct, alter, improve, demolish, or repair any structure, prior to its issuance, also requires the applicant for such permit to file a signed statement that he or she is licensed pursuant to the provisions of the Contractors License Law (Chapter 9 (commencing with Section 7000) of Division 8 of the Business and Professions Code) or that he or she is exempt therefrom and the basis for the alleged exemption. Any violation of Section 7031.5 by any applicant for a permit subjects the applicant to a civil penalty of not more than five hundred dollars ($500.00);

_____ I, as a owner of the property, or my employees with wages as their sole compensation, will do the work, and the structure is not intended or offered for sale (Sec. 7044, Business and Professional Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who does such work himself or herself or through his/her own employees, provided that such improvements are not intended or offered for sale. If, however, the building or improvement is sold within one year of completion, the owner-builder will have the burden of proving that he/she did not build or improve for the purpose of sale.)

_____ I, as owner of the property, am exclusively contracting with licensed contractors to construct the project (Sec. 7044, Business and Professions Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who contracts for such projects with a contractor(s) licensed pursuant to the Contractors License Law).

_____ I am exempt under Sec._____ B & PC for this reason:_____

Date_____ Owner Signature_____

IN ISSUING THIS BUILDING PERMIT, the applicant represents, and the city relies on the representation of the applicant, that the applicant verified all measurements and locations shown on the application or accompanying drawings and that the improvement to be constructed does not violate any law or private agreement relating to permissible or prohibited locations for such improvements. This building permit does not authorize any illegal location of any improvement or the violation of any private agreement relating to location of improvements.

I certify that I have read this application and state that all information is correct. I agree to comply with all city and county ordinances and state laws relating to building construction and herby authorize representative(s) of this city to enter upon the abovementioned property for inspection purposes.

Date 8-16-05 Applicant/Agent Signature_____

WORKER'S COMPENSATION DECLARATION: I hereby affirm under penalty of perjury one of the following declarations:
_____ I have and will maintain a certificate of consent to self-insure for workers' compensation as provided for by Section 3700 of the Labor Code, for the performance of work for which the permit is issued.

CR I have and will maintain workers' compensation insurance, as required by Section 3700 of the Labor Code, for the performance of the work for which this permit is issued. My workers' compensation insurance carrier and policy number are:

Carrier ZURICH AMERICAN INS CO Policy Number WC 3495307-05 Exp Date 10/01/2005

_____ (This section need not be completed if the permit is for $100 or less) I certify that in the performance of the work for which this permit is issued, I shall not employ any person in any manner so as to become subject to the workers' compensation laws of California and agree that if I should become subject to the workers' compensation provisions of Section 3700 of the Labor Code, I shall forthwith comply with those provisions.

Date 8-16-05 Applicant Signature_____

WARNING: FAILURE TO SECURE WORKER'S COMPENSATION COVERAGE IS UNLAWFUL AND SHALL SUBJECT AN EMPLOYER TO CRIMINAL PENALTIES AND CIVIL FINES UP TO ONE HUNDRED THOUSAND DOLLARS ($100,000) IN ADDITION TO THE COST OF COMPENSATION, DAMAGES AS PROVIDED FOR IN SECTION 3706 OF THE LABOR CODE, INTEREST AND ATTORNEY'S FEE.

THIS PERMIT SHALL EXPIRE BY LIMITATION IF WORK IS NOT COMMENCED WITHIN 180 DAYS.

FINAL AIR BALANCE COMPANY, INC.

Preliminary Report
NOT Certified

Date: 10-18-05

Sheet no: 1

VAV TEST SHEET

JOB NAME: CBBD - Medical Plaza - 6th Floor

SYSTEM: VAV-6-16 thru VAV-6-18

All Boxes at Max Airflows

Room No.	Terminal No.	Terminal Type	Terminal Size	Effective Area	Max Design FPM	Max Design CFM	Max Final FPM	Max Final CFM	Minimum CFM Design	Minimum CFM Final	~~Notes~~
	VAV-6-16		12" ø								
7	16-1	CR	12x12	FL	CL	630	FL	640	DNL		
6	16-2	↓	10x10	↓	↓	320	↓	310	↓		
5	16-3	↓	10x10	↓	↓	340	↓	325	↓		
	Factor=	0.69			Cold	1290		1275	325	325	1165
					Hot	650		640	325	325	
	VAV-6-17		10" ø								
1	17-1	CR	10x10	FL	FH	320	FL	325	DNL		
2	17-2	↓	8x8	↓	↓	215	↓	210	↓		
3	17-3	↓	↓	↓	↓	210	↓	205	↓		
4	17-4	↓	↓	↓	↓	310	↓	200	↓		
	Factor=	0.73			Cold	955		940	230	225	910
					Hot	480		475	230	225	
	VAV-6-18		9" ø								
Conference	18-1	CR	10x10	FL	FL	450	FL	450	190	190	
	Factor=	0.68				1150		450	190	190	433

FH = Direct read with flow hood

Factor = Calibration Factor

Remarks:

Microf, Inc

FINAL AIR BALANCE COMPANY, INC.

Preliminary Report
NOT Certified

Date: 10-18-05

Sheet no: 2

VAV TEST SHEET

JOB NAME: CBBD - Municipal Bldg - 5th Floor

SYSTEM: VAV-8-19

All Boxes at MAX Air Flow

Room No.	Terminal No.	Terminal Type	Terminal Size	Effective Area	Max Design FPM	Max Design CFM	Max Final FPM	Max Final CFM	Minimum CFM Design	Minimum CFM Final	Notes
	VAV-8-19		16" ø								
Reception	19-1	CR	10x10	FH	FH	275	FH	360	DNC		
IT	19-2	↓	6x6	↓	↓	100	↓	90	↓		
Hall	19-3		8x8			130		130			
Break	19-4		8x8			160		165			
Hall	19-5		6x6			125		130			
Copy	19-6	↓	10x10	↓	↓	360	↓	355	↓		
	Factor:	0.75				1165		1170	230	230	1115

FH = Direct read with flow hood

Factor = Calibration Factor

Remarks: