Section 2406.2 & 2406.4 Item 9 GLAZING IN HAZARDOUS LOCATIONS

UBC page 1-332

- Hazardous location provisions of Section 2406 now apply to glazing in walls and fences enclosing swimming pools and spas.

- All following conditions must apply:
  - -Bottom edge of glazing is less than 60 inches above the pool/spa decking.
  - -Glazing at or within 5 feet of swimming pool deck or spa deck intended for pedestrian traffic.

- Provision applies to lights of any size.



9. Glazing in walls and fences used as the barrier for indoor and outdoor swimming pools and spas when all of the following conditions are present:

9.1 The bottom edge of the glazing is less than 60 inches (1525 mm) above the pool side of the glazing.

9.2 The glazing is within 5 feet (1525 mm) of a swimming pool or spa deck area.

10. Glazing in walls enclosing stairway landings or within 5 feet (1525 mm) of the bottom and top of stairways where the bottom edge of the glass is less than 60 inches (1525 mm) above a walking surface.