

BUILDING DIVISION—BUILDING INSPECTOR'S REPORT CARD

1st Permit

TYPE VII BUILDINGS

PERMIT NO. 5765	LOCATION 415-19 th St	
DATE 3/1/30	PURPOSE Sanitary for Fire Department	ROOMS APTS.
ZONE General Commercial	OWNER R. Weidmann	PHONE
	ARCH'T	
	CONT'R Quinn	
	VAL. 3500	STORIES 2
		SIZE

FOUNDATION	STORY	BSMT	1	2	3	ROOF		
Ex Wall	Joists						Chimneys	Cement Tests
	Beams and Girders						Fire Place	
Int Wall	Studs and Columns						Gas Water Heater	
	Bridging Fire Stops						Heater Closet	
Piers	Fire Escape Stand Pipes						Furnace	Window Courts
	Metal Lath						Boiler Room	
	Stairs						Elevator Shaft	

DATE	CONDITION OF WORK—REMARKS
3/12/30	Made Preliminary Inspection of 1 st Story of 2-Story building to be remodeled for stores.
	Give information & order to put in 2x6 brds. over and concrete base 2x8 floor joists 16" c
	and wood floor - joists to rest on present 2x8"
	1) If mud fills mud will install 5 Vents below floor entrance door to be at corner All complete
3/15/30	2 nd HSP frame - All FIRESTOPS in place OK All complete
3/17/30	3 rd " 1 st FLOOR - CEILING - ONLY. Walls to be 1x6. All
4/4/30	4 th HSP Remodeling of 1 st Story fire store completed
	Street cleaned up OK
4/4/30	COMPLETED AND O.K. Alden H. Campbell INSPECTOR