



BUILDING DIVISION-BUILDING INSPECTOR'S REPORT CARD

TYPE BUILDINGS

PERMIT NO. <i>B-10449</i>	LOCATION <i>1315 - 4th Ave</i>
DATE <i>6/11/42</i>	PURPOSE <i>Hang elec. sign</i>
ZONE	OWNER <i>Gift Liquor Store</i>
	ARCH'T.
	CONTR. <i>Elec. Sign Serv. Co.</i>

VAL. <i>10000</i>	STORIES	ROOMS	APTS.	SIZE
-------------------	---------	-------	-------	------

LIGHT SHAFTS		ELEVATOR SHAFTS	
VENT SHAFTS		BOILER ROOMS	
OWNER'S INSPECTOR		SPRINKLER SYSTEM	
LATH		GAS VENTS	
FIRE ESCAPES		CHIMNEYS	
STAND PIPES		SKYLIGHTS	

DATE	CONDITION OF WORK-REMARKS
6/11/42	<p>Made inspection of Horizontal Double Face Electric Sign hung 10 ft above sidewalk and 3 ft inside face line of curb.</p> <p>Sign is anchored to Brick Fire Wall with Angle Braces back to Roof and braced with Guy Wires on Top & Each side diagonally in Rdg.</p> <p>O.K. </p>
6/24/42	<p>COMPLETE AND O. K. </p> <p style="text-align: right;">INSPECTOR</p>