

R150 7441-450

BUILDING DIVISION — BUILDING INSPECTOR'S REPORT CARD

\$168.50

TYPE BUILDINGS

R169 721-23 File

PERMIT NO. E-8050	LOCATION 1410 - 21st Street	A-2	
DATE Aug 5-64	PURPOSE Const. office & restaurant addn. to	OWNER Henry Milano Same / office bldg.	
ZONE C-2	ARCH'T Roy Swedin	452-6593	
	CONT'R F. Marsalla	3990-71st Street	
VAL. \$66,000.	STORIES	ROOMS	APTS. 2,560 sq. ft. 2,560 sq. ft.
INSP.	DATE	BLDG. TYPE V no hr. ¹	OCCUPANCY GROUP ¹ -2 PHONE (O) (C)
FORM			
JOIST			
FRAME	12-28-64	<i>[Signature]</i>	
SHEET ROCK	12-28-64	<i>[Signature]</i>	
FINAL	5-7-65	<i>[Signature]</i>	

[Handwritten note]



DATE	SPECIAL CONDITIONS OF WORK -- REMARKS
9-17-64	P.T. NO Insp. Card on job - steel not in place Hammons
10-16-64	P.T. membrane not ready - Fuller
10-20-64	Slab. OK - Hammons
10-23-64	A1 - WEST WALL A1 - NORTH WALL } O.K. Fuller
10-26-64	8' BB. Called in But unable to make inspection
10-27-64	12' BB OK - Hammons
10-28-64	parpet wall OK - Hammons.
11-30-64	Roof nail OK - Hammons
12-8-64	P.T. revised plans must be submitted. Hammons
12-14-64	Frame OK except Kitchen + storage room Hammons
12-24-64	P.T. S.R. Not Ready Scarbato
3-1-65	P.T. TICKETS NOT LABELED. SEAL AROUND ALL PIPES BETWEEN 1 ST & 2 ND FLOOR. AIR COND. GRILLES MISSING. NO JOB CARD Loren
3-9-65	P.T. Fun in restroom - Occupied sign - poor thru Block Wall
COMPLETE AND OK	on 1 st floor not on plans - Lock door to roof - Loren

INSPECTOR