

PERMIT NO.

0012933

OFFICE OF SACRAMENTO
COUNTY BUILDING DEPARTMENT
SACRAMENTO, CALIFORNIA

AREA NO.

1-R

WHEN CORRECTIONS HAVE BEEN MADE, CALL **264-5191** FOR REINSPECTION OF WORK.

DESCRIPTION

93 Celoms

INSPECTION
REQUESTED

Frame

THE CITY DESIGNER, ENGINEER, PLUMBING, MECHANICAL, ELECTRICAL
INSPECTOR THIS DAY INSPECTED THE STRUCTURE FOR THE REQUESTED INSPECTION AND FOUND THE
WORK TO BE IN ACCORDANCE WITH THE CALIFORNIA STATE LAWS GOVERNING SAME:

Provide positive transfer
from point loads at
trimmers to foundation

Provide min 36" deep
landing at ext. door.

INSPECTOR

DATE


11/30/00

BUILDING INSPECTIONS 264-5716

INSPECTOR'S COPY

Mrs Steve Trelis
 143 Colma way
 Sacramento Ca.

This set of plans and specifications must be kept on the job at all times and it is unlawful to make any changes or alterations from the same without written permission from the Building Inspection Division.
 The approval of this plan and specification SHALL NOT be held to permit or approve the violation of any City Ordinance or State Law.




ISSUED

001198 2000

DEPT OF SACRAMENTO
 BUILDING INSPECTION DIVISION

- 1.) Move existing light fixture
- 2.) New step below door
- 3) New Header to be 2x12 or 4x12.



* Verify adequate brace
 wall panels along these lines

Matt P. 10/25/10

