

BUILDING DIVISION-BUILDING INSPECTOR'S REPORT CARD

TYPE BUILDINGS

PERMIT NO. 8349	LOCATION 3657 N Ln
DATE 8/3/31	PURPOSE Add Sleeping Porch
OWNER Mrs F Dunning	PHONES
ZONE 2	ARCH'T Dunning
VAL. 95-	CONT-R Dunning

VAL.	STORIES	ROOMS	APTS.	SIZE
Light Shafts			Elevator Shafts	
Vent Shafts			Boiler Rooms	
Owner's Inspector			Sprinkler System	
Lath			Gas Vents	
Fire Escapes			Chimneys	
Stand Pipes			Skylights	

DATE	CONDITION OF WORK-REMARKS
8/5/31	1 ST / N.S.P. OF SLEEPING PORCH ADDITION
	Notified Contractor mud-sill should be raised up 2" above ground on concrete or brick piers
	A.W. Campbell
8/8/31	Sleeping Porch Addition completed
	Note Owner did not raise mud sill above ground; otherwise addition completed.
8/18/31	COMPLETE AND O.K. <i>Alfred W. Campbell</i> INSPECTOR