

R. 206, F 650-651

BUILDING DIVISION — BUILDING INSPECTOR'S REPORT CARD

\$25.00

TYPE BUILDINGS

PERMIT NO. F-5957	LOCATION 1236 - D Street		A-2	
DATE Nov. 25-66	PURPOSE	Repair fire damage to exist. Apt.		
ZONE R-5	OWNER	P. Masaki 481 - Arden Way		
	ARCH'T			
	CONTR	Statewide Const. 1209 21rst Street		
VAL. \$5,200.	STORIES	ROOMS	APTS.	SIZE
INSP.	DATE	BLDG. TYPE V no hr	OCCUPANCY GROUP H-1	PHONE (O) (C) 448-8241
FORM				
JOIST				
FRAME	12/8/66	Barbato		
SHEET ROCK	12-20-67	Lath ok. Barbato		
FINAL	1-19-67	J Barbato <i>ent</i>		

DATE	SPECIAL CONDITIONS OF WORK — REMARKS
3-28-67	Pt. Canal - 1 3/4" solid core doors
	required from R. Adams to stairs
	Enclosure Barbato
3-29-67	Pt. Canal - 1 3/4" solid. required in
	Kitchen Barbato
	<div style="display: flex; justify-content: space-between;"> COMPLETE AND OK INSPECTOR </div>

117