CITY OF SACRAMENTO

1231 I Street, Sacramento, CA 95814

Permit No: 0520078
Insp Area: 1
Thos Bros: 297D3

PAID
CITY OF SACRAMENTO
JUN 26 2006

Site Address: 921 11TH ST SAC
Parcel No: 006-0047-011

THE ELKS TOWER
NEW CITY HALL

Type: ACOM
Housing (Y/N): N

CONTRACTOR
JOHN F OTTO
1717 2ND ST
SACRAMENTO CA 95814

OWNER
UTAH PARTNERS LLC
6601 26TH ST
RIO LINDA, CA 95673

ARCHITECT
PETER DANNENFELSER

Nature of Work: MATRIX PROJECT- CONSTRUCTION OF NEW SMUD VAULT

CONSTRUCTION LENDING AGENCY : I hereby affirm under penalty of perjury that there is a construction lending agency for the performance of the work for which this permit is issued (Sec. 3097, Civ. C).

Lender's Name_____ Lender'sAddress_____

LICENSED CONTRACTORS DECLARATION: I hereby affirm under penalty of perjury that I am licensed under provisions of Chapter 9 (commencing with section 7000) of Division 3 of the Business and Professions Code and my license is in full force and effect.

X License Class B/A License Number 178809 Date 6/26/06 Contractor Signature Khachgyan for

OWNER-BUILDER DECLARATION: I hereby affirm under penalty of perjury that I am exempt from the contractors License Law for the following reason (Sec. 7031.5, Business and Professions Code; any city or county which requires a permit to construct, alter, improve, demolish, or repair any structure, prior to its issuance, also requires the applicant for such permit to file a signed statement that he or she is licensed pursuant to the provisions of the Contractors License Law (Chapter 9 (commencing with Section 7000) of Division 8 of the Business and Professions Code) or that he or she is exempt therefrom and the basis for the alleged exemption. Any violation of Section 7031.5 by any applicant for a permit subjects the applicant to a civil penalty of not more than five hundred dollars ($500.00);

_____ I, as a owner of the property, or my employees with wages as their sole compensation, will do the work, and the structure is not intended or offered for sale (Sec. 7044, Business and Professional Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who does such work himself or herself or through his/her own employees, provided that such improvements are not intended or offered for sale. If, however, the building or improvement is sold within one year of completion, the owner-builder will have the burden of proving that he/she did not build or improve for the purpose of sale.)

_____ I, as owner of the property, am exclusively contracting with licensed contractors to construct the project (Sec. 7044, Business and Professions Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who contracts for such projects with a contractor(s) licensed pursuant to the Contractors License Law).

_____ I am exempt under Sec._____ B & PC for this reason:_____

Date_____ Owner Signature_____

IN ISSUING THIS BUILDING PERMIT, the applicant represents, and the city relies on the representation of the applicant, that the applicant verified all measurements and locations shown on the application or accompanying drawings and that the improvement to be constructed does not violate any law or private agreement relating to permissible or prohibited locations for such improvements. This building permit does not authorize any illegal location of any improvement or the violation of any private agreement relating to location of improvements.

I certify that I have read this application and state that all information is correct. I agree to comply with all city and county ordinances and state laws relating to building construction and herby authorize representative(s) of this city to enter upon the abovementioned property for inspection purposes.

X Date 6/26/06 Applicant/Agent Signature Khachgyan for

WORKER'S COMPENSATION DECLARATION: I hereby affirm under penalty of perjury one of the following declarations:
_____ I have and will maintain a certificate of consent to self-insure for workers' compensation as provided for by Section 3700 of the Labor Code, for the performance of work for which the permit is issued.

__✓__ I have and will maintain workers' compensation insurance, as required by Section 3700 of the Labor Code, for the performance of the work for which this permit is issued. My workers' compensation insurance carrier and policy number are:

Carrier MAJESTIC INSURANCE Policy Number C200002519-05 Exp Date 07/01/2006

_____ (This section need not be completed if the permit is for $100 or less) I certify that in the performance of the work for which this permit is issued, I shall not employ any person in any manner so as to become subject to the workers' compensation laws of California and agree that if I should become subject to the workers' compensation provisions of Section 3700 of the Labor Code, I shall forthwith comply with those provisions.

X Date 6/26/06 Applicant Signature Khachgyan for

WARNING: FAILURE TO SECURE WORKER'S COMPENSATION COVERAGE IS UNLAWFUL AND SHALL SUBJECT AN EMPLOYER TO CRIMINAL PENALTIES AND CIVIL FINES UP TO ONE HUNDRED THOUSAND DOLLARS ($100,000) IN ADDITION TO THE COST OF COMPENSATION, DAMAGES AS PROVIDED FOR IN SECTION 3706 OF THE LABOR CODE, INTEREST AND ATTORNEY'S FEE.

~~THIS PERMIT SHALL EXPIRE BY LIMITATION IF WORK~~ IS NOT COMMENCED WITHIN 180 DAYS.

Permit # 0520078 921 11th ST

GROUND FAULT TEST REPORT

CUSTOMER VASKO	LOCATION EIK Bldg. SAC	DATE 12-14-00
	JOB NUMBER	TECH. AM
DESIGNATION MCC	TEST EQUIP. USED MS 2	

NAMEPLATE DATA

SWBD MFG. SIEMENS	SERIAL # 17-50874-A00010	MAIN OVERCURRENT DEV. X C.B. ___ SWITCH	MFG./TYPE SIEMENS WLL2F320
GROUND FAULT SYSTEM TYPE (CIRCLE ONE) -02 RESIDUAL ZERO SEQ. SOURCE GND.		RELAY MFG. —	RELAY CAT. # —
CURRENT RANGES 100-1200A	TIME RANGES .1-.5 IDT	CURRENT SETTING 300A IDT	TIME SETTING .35sec

VISUAL AND MECHANICAL INSPECTIONS

ITEM	STATUS	NOTES	ITEM	STATUS	NOTES
GROUND POINT	A		TEST PANEL OPERATION	NA	
NEUTRAL SENSOR LOCATION	A		CONTROL POWER XFMR	NA	
NEUTRAL SENSOR POLARITY	A		ZONE INTERLOCKING	NA	
MAIN BONDING JUMPER	A		MULTIPLE SOURCE SCHEME	NA	
REDUCED VOLTAGE TEST	NA		NEUTRAL CONDUCTOR	A	

ELECTRICAL TESTS

PICK UP CURRENT	318 AMPS	NEUTRAL INSULATION TO GROUND	2K+ MEGOHMS

% PICKUP	PRIMARY TEST CURRENT (AMPS)	MEASURED TIME (SEC)	ACCEPTABLE TIME (SEC)
150%	~477	.36	.5-.4 SEC

NOTES (PASS) FAIL

ALL NEUTRALS ADDED MUST BE CLEAR OF GLASS

*STATUS A - ACCEPTABLE R - NEEDS REPAIR OR REPLACEMENT X - UNACCEPTABLE NA - NOT APPLIC.

INDUSTRIAL TESTS INC.

"AN ELECTRICAL TESTING CONTRACTOR"

916-859-5959