

R325 F98

BUILDING DIVISION — BUILDING INSPECTOR'S REPORT CARD

\$33.00

TYPE BUILDINGS

PERMIT NO. H-6058		LOCATION 2183 - Sarazen Avenue A-4			
DATE Mar. 28-72		PURPOSE Const. family room to rear of dwelling			
ZONE R-1		OWNER L. R. McQuillon Same			
		ARCH'T			
		CONT'R Owner Same 421 1478			
VAL. \$5,000.		STORIES	ROOMS	APTS.	SIZE 368 sq. ft.
INSP.	DATE	BLDG. TYPE		OCCUPANCY GROUP	PHONE (O) (C)
FORM	<i>4-14-72</i>	<i>McQuillon</i>			
JOIST					
FRAME	<i>7-2-72</i>	<i>Fuller</i>			
SHEET ROCK					
FINAL	<i>8-15-73</i>	<i>Dana Fuller</i>			

1. Check for correct zoning classification.
 2. Check for correct building type.
 3. Check for correct occupancy group.
 4. Check for correct fire alarm and fire extinguisher requirements.
 5. Check for correct fire escape requirements.
 6. Check for correct fire door and fire window requirements.
 7. Check for correct fire protection requirements.
 8. Check for correct fire alarm and fire extinguisher requirements.
 9. Check for correct fire escape requirements.
 10. Check for correct fire door and fire window requirements.
 11. Check for correct fire protection requirements.

DATE	SPECIAL CONDITIONS OF WORK — REMARKS
6-30-72	P. Frank not ready J. Barber
8-9-72	By final - 210 on time Gallaway
1-3-73	It. final - glass in sliding door should be tempered glass Barber
	COMPLETE AND OK INSPECTOR