

R-99 F 539-540

BUILDING DIVISION — BUILDING INSPECTOR'S REPORT CARD \$16.00

TYPE BUILDINGS

PERMIT NO. E-1228	LOCATION 3033 - 60th Street	A-1
DATE May 2-62	PURPOSE Enlarge 3 rooms & add 1 room to dwlg.	
	OWNER Charles O'Connell	Same
ZONE R-1	ARCH'T Mayer & Donahue	IV 3-1772 2400-Fair Oaks Blvd.

VAL. \$3,000.	STORIES	ROOMS	APTS.	SIZE 353 sq. ft.
---------------	---------	-------	-------	---------------------

INSP.	DATE	BLDG. TYPE	OCCUPANCY GROUP
FORM	5-8-62	Fuller	
JOIST	5-11-62	Callaway	
FRAME	6-19-62	Fuller	
SHEET ROCK	6-26-62	Bishop	
FINAL	2-14-63	E. Larsen	

DATE	SPECIAL CONDITIONS OF WORK — REMARKS
5-4-67	Plaster in chimney job. Birds in frame - blocking on ceiling
6-13-67	Cracks. Report that plaster to be Drying had to be mended. Plaster rubbed where needed. Also in frame. Interior wall not on
6-13-67	2x8 ceiling joists not properly blocked. Filled
1-30-68	Call Contractor. Owner doing own painting. Filled
	COMPLETE AND OK
	INSPECTOR