

CITY OF SACRAMENTO
1231 I Street, Sacramento, CA 95814

Permit No: 0303377

Insp Area: 3

Thos Bros: 318 D3

Site Address: 4410 POWER INN RD SAC

Parcel No: 061-0082-014

Sub-Type: REM

Housing (Y/N): N

CONTRACTOR

WEST FORK CONSTRUCTION
4701 24TH ST SUITE 1A
SACRAMENTO CA 95822

OWNER

SICHEL SHIRLEY P/TR
233 SANSOME ST STE 800
SAN FRANCISCO CA 94104-2314

ARCHITECT

Nature of Work: remodel of office bldg to residential shelter and site improvements

CONSTRUCTION LENDING AGENCY : I hereby affirm under penalty of perjury that there is a construction lending agency for the performance of the work for which this permit is issued (Sec. 3097, Civ. C).

Lender's Name _____ Lender's Address _____

LICENSED CONTRACTORS DECLARATION: I hereby affirm under penalty of perjury that I am licensed under provisions of Chapter 9 (commencing with section 7000) of Division 3 of the Business and Professions Code and my license is in full force and effect.

License Class B License Number 724016 Date 12/4/03 Contractor Signature [Signature]

OWNER-BUILDER DECLARATION: I hereby affirm under penalty of perjury that I am exempt from the contractors License Law for the following reason (Sec. 7031.5, Business and Professions Code; any city or county which requires a permit to construct, alter, improve, demolish, or repair any structure, prior to its issuance, also requires the applicant for such permit to file a signed statement that he or she is licensed pursuant to the provisions of the Contractors License Law (Chapter 9 (commencing with Section 7000) of Division 8 of the Business and Professions Code) or that he or she is exempt therefrom and the basis for the alleged exemption. Any violation of Section 7031.5 by any applicant for a permit subjects the applicant to a civil penalty of not more than five hundred dollars (\$500.00);

_____, I, as a owner of the property, or my employees with wages as their sole compensation, will do the work, and the structure is not intended or offered for sale (Sec. 7044, Business and Professional Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who does such work himself or herself or through his/her own employees, provided that such improvements are not intended or offered for sale. If, however, the building or improvement is sold within one year of completion, the owner-builder will have the burden of proving that he/she did not build or improve for the purpose of sale.)

_____, I, as owner of the property, am exclusively contracting with licensed contractors to construct the project (Sec. 7044, Business and Professions Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who contracts for such projects with a contractor(s) licensed pursuant to the Contractors License Law).

_____ I am exempt under Sec. _____ B & PC for this reason: _____

Date _____ Owner Signature _____

IN ISSUING THIS BUILDING PERMIT, the applicant represents, and the city relies on the representation of the applicant, that the applicant verified all measurements and locations shown on the application or accompanying drawings and that the improvement to be constructed does not violate any law or private agreement relating to permissible or prohibited locations for such improvements. This building permit does not authorize any illegal location of any improvement or the violation of any private agreement relating to location of improvements.

I certify that I have read this application and state that all information is correct. I agree to comply with all city and county ordinances and state laws relating to building construction and hereby authorize representative(s) of this city to enter upon the abovementioned property for inspection purposes.

Date 12/4/03 Applicant/Agent Signature [Signature]

WORKER'S COMPENSATION DECLARATION: I hereby affirm under penalty of perjury one of the following declarations:

_____ I have and will maintain a certificate of consent to self-insure for workers' compensation as provided in Section 3700 of the Labor Code, for the performance of work for which the permit is issued.

_____ I have and will maintain workers' compensation insurance, as required by Section 3700 of the Labor Code, for the performance of the work for which this permit is issued. My workers' compensation insurance carrier and policy number are:

Carrier STATE FUND

Policy Number 046001030701

PAID
CITY OF SACRAMENTO
DEC 04 2003
NORTH PERMIT CENTER

_____, (This section need not be completed if the permit is for \$100 or less) I certify that in the performance of the work for which this permit is issued, I shall not employ any person in any manner so as to become subject to the workers' compensation laws of California and agree that if I should become subject to the workers' compensation provisions of Section 3700 of the Labor Code, I shall forthwith comply with those provisions.

Date 12/4/03 Applicant Signature [Signature]


WARNING: FAILURE TO SECURE WORKER'S COMPENSATION COVERAGE IS UNLAWFUL AND SHALL SUBJECT AN EMPLOYER TO CRIMINAL PENALTIES AND CIVIL FINES UP TO ONE HUNDRED THOUSAND DOLLARS (\$100,000) IN ADDITION TO THE COST OF COMPENSATION, DAMAGES AS PROVIDED FOR IN SECTION 3706 OF THE LABOR CODE, INTEREST AND ATTORNEY'S FEE.

THIS PERMIT SHALL EXPIRE BY LIMITATION IF WORK IS NOT COMMENCED WITHIN 180 DAYS.

CITY OF SACRAMENTO

CERTIFICATE OF OCCUPANCY

For Information Contact (916) 264-5716

Building Address: 4410 POWER INN RD Permit No.: 0303377
Building Use: OFFICE BLD. DBA: SAINT JOHN'S SHELTER Occupancy: R-1/A-3B
Building Owner: SICHEL SHIRLEY Construction Type: V-N
Owner Address: 233 SANSOME STREET STE 800 Sprinkled? [] Yes [X] No
SAN FRANCISCO, CA. 94104
Portion of Building Occupied: ENTIRE Area: UNKNOWN Sq. Ft.
06-22-2004
Date By: (Print)  Sign DENNIS RICHARDSON
CHIEF BUILDING OFFICIAL

[Finaled By:DS,LH,RH,CDY,PWC]


This Certificate, issued pursuant to the requirements of Section 109 of the Uniform Building Code, certifies that at time of issuance the described portion of the building has been inspected for compliance with the Uniform Building Code, as adopted per Title 15 of the Sacramento City Code for the group and division of occupancy and use for which the proposed occupancy is classified. Issuance of this certificate shall not be construed as an approval of a violation of any Codes, or Federal, State and City Laws or Ordinances. Certificates presuming to give authority to such violation shall not be valid. This certificate shall be posted in a conspicuous place on the premises and shall not be removed except by the Chief Building Official. No changes shall be made in the character of occupancy or use without approval of the Chief Building Official.

POST IN A CONSPICUOUS PLACE

CITY OF SACRAMENTO

CERTIFICATE OF OCCUPANCY

For Information Contact (916) 264-5716

Building Address: 4410 POWER INN RD Permit No.: 0303377
Building Use: OFFICE BLD. DBA: SAINT JOHN'S SHELTER Occupancy: R-1/A-3B
Building Owner: SICHEL SHIRLEY Construction Type: V-N
Owner Address: 233 SANSOME STREET STE 800 Sprinkled? [] Yes [X] No
SAN FRANCISCO, CA. 94104
Portion of Building Occupied: ENTIRE Area: UNKNOWN Sq. Ft.
06-22-2004
Date By: (Print)  Sign **DENNIS RICHARDSON**
CHIEF BUILDING OFFICIAL

[Finaled By:DS,LH,RH,CDY,PWC]

This Certificate, issued pursuant to the requirements of Section 109 of the Uniform Building Code, certifies that at time of issuance the described portion of the building has been inspected for compliance with the Uniform Building Code, as adopted per Title 15 of the Sacramento City Code for the group and division of occupancy and use for which the proposed occupancy is classified. Issuance of this certificate shall not be construed as an approval of a violation of any Codes, or Federal, State and City Laws or Ordinances. Certificates presuming to give authority to such violation shall not be valid. This certificate shall be posted in a conspicuous place on the premises and shall not be removed except by the Chief Building Official. No changes shall be made in the character of occupancy or use without approval of the Chief Building Official.

POST IN A CONSPICUOUS PLACE

APPLICATION FOR COMMERCIAL BUILDING PERMIT

CITY OF SACRAMENTO
DEVELOPMENT SERVICES DIVISION
PERMIT SERVICES SECTION

231 I Street, Rm. 200
 Sacramento, CA 95814 (916) 264-7619 FAX 264-7046

ACTIVITY # <u>D303371</u>	Insp. Area _____
---------------------------	------------------

Applicant **MUST** complete ALL Unshaded areas

ADDRESS 4410 POWER INN ROAD Suite _____
 PERMIT # 061-0082-014

CONTACT Name <u>JASON SILVA</u> Street Address <u>3540 FOLSOM BLVD</u> City/State/Zip <u>SACTO, CA 95816</u> Phone <u>(916) 453-1234</u> FAX <u>453-1236</u> E-mail: <u>jsilva@db-arch.com</u>	LICENSED CONTRACTOR Lic No. # _____ Name _____ Address _____ City/State/Zip _____ Phone _____ FAX _____ E-mail: _____
ARCHITECT/ENGINEER Name <u>SAME</u> Address _____ City/State/Zip _____ Phone _____ FAX _____ E-mail: _____	OWNER Name <u>PAVEL PROPERTIES</u> Address <u>3031 F STREET SUITE 201</u> City/State/Zip <u>SACTO, CA 95816</u> Phone <u>(916) 325-5480</u> FAX <u>325-5454</u> E-mail: _____

Will permittee have any employees on the jobsite? No Yes → INSURANCE CO: _____
 WORKER'S COMPENSATION POLICY # _____ EXPIRATION DATE: _____

NATURE OF WORK IN DETAIL: Change of use from office to shelter

OCCUPANT/TENANT: St. Johns VALUATION: \$ 1,100,000

LOAD STATUS:		S.C.A.T.									
JOB DESCRIPTION		BLDG	SHELL	APT	TI ()	REM ()	SW	FIRE	ADD	OTH	
INSPECTION DISCIPLINES			BLDG	MECH	PLUMB	ELEC		SITE	FIRE		
Stories	1st flr Area	Total Area	Use Zone	Occp Group	Const type	Fire Req. Y / N		Fed Code	Vio. File		
						SPR	ALARM		[H]	[Quad]	
<u>B</u>	<u>L</u>	<u>P</u>	<u>M</u>	<u>E</u>	<u>F</u>	<u>S</u>			<u>PW</u>	<u>UTIL</u>	

COMMENTS: _____

REGIONAL SANITATION FEES? Yes No HEALTH DEPARTMENT? Yes No
 WATER FLOW TEST FOR NEW BUILDINGS OR ADDITIONS? Provided Faxed

AIRTEX

LETTER OF TRANSMITTAL

Date: 6/7/2004	Job: ST. JOHN'S SHELTER
WEST FORK CONSTRUCTION, INC.	
attn: Brian	

- We Are Sending You: Guarantee Sent Via: FAX
- Agreement/Contract/Invoice Change Order Prints O & M's
- Lien Release Copy of Letter Check Reports

COPIES	DATE	NO.	DESCRIPTION
1	5/6/2004		AIR BALANCE REPORTS PAGES 1-15

- For Your Use Approved as Submitted For Review and Comment
- For Approval Approved as Noted Return 1 Fully Executed Copy of Contract
- FOR BIDS DUE _____ Resubmit _____ Copies for Approval

NOTE: _____

SIGNED: Ronald L. Jankert

CONDITIONING AND HEATING, INC. - 3199 Fitzgerald Road - Rancho Cordova, CA 95742
 (916) 852-8672 - Fax (916) 852-8459 - Lic. 614060

IF ENCLOSURES ARE NOT AS NOTED, KINDLY NOTIFY US AT ONCE.

AIRTEX

Job No: WF-33 Area Served: ADMINISTRATION
 Date: May 06, 2004 Page: 1 of 15 Unit No: HP-1 / ZD-1

Motor Nameplate Data			Unit Nameplate Data		Data Item	Test 1	Test 2	Test 3	
MFR:	GE		MFR:	YORK		Volts			214
FR:	N/A		M/N:	82S9060A25B		AMPS			4
HP:	3/4	V: 208/230	S/N:	NNPM348886		BHP			N/A
FLA:	4.1	PH: 1	Shave Data Blower			RPM			HI SPD
SP:	N/A	RPM: 1075	P/N:	N/A		SP -			0.28
Data			Shaft:	N/A		SP +			0.34
P/N:	N/A		Relts:	N/A		TSP			0.62
Data			Fan Design Data			Filter SP			0.02
Adj:	N/A		CFM:	1800		CFM Total			2040
Fixed:	N/A		SP:	0.7		CFM RA			1455
			RPM:	N/A		CFM OA			585
			BHP:	N/A					
			OSA:	N/A					

Room	Opening		Factor	CFM	CFM	CFM	CFM
130	30	S	10	290	295	310	325
143	51	S	10	285	370	295	330
107	52	S	6	60	110	110	75
106	53	S	12	465	535	545	530
102	54	S	10	360	420	425	405
103	55	S	10	340	360	345	375
TOTAL				1800	2090	2030	2040
143	56	R	12	455	635	645	605
	57	R	6	50	90	90	80
	58	R	10	305	95	100	300
	59	R	10	300	325	330	305
	60	R	10	155	305	310	165
TOTAL				1265	1450	1475	1455
OSA				535	640	555	585

Remarks: VAV MIN .75 VAC
MAX 1.75 VAC

AIRTEX AIR CONDITIONING AND HEATING, INC. - 3199 Fitzgerald Road - Rancho Cordova, CA 95742
 (916) 852-8672 Fax (916) 852-8459 - Lic# 614060

AIRTEX

Job No: WF-33 Area Served: INTERIOR LIVING ROOM
 Date: May 06, 2004 Page: 2 of 15 Unit No: HP-2

Motor Nameplate Data		Unit Nameplate Data		Data/Item	Test 1	Test 2	Test 3
MFR:	GE	MFR:	YORK	Volts			214
FR:	N/A	M/N:	* N/A	AMPS			5
HP:	3/4 V: 208/230	S/N:	* N/A	BHP			N/A
FLA:	5 PH: 1	Sheave Data-Blower		RPM			HI SPD
SF:	N/A RPM: 1075	P/N:	N/A	SP -			0.43
Sheave Data		Shaft:	N/A	SP +			0.23
P/N:	N/A	Belts:	N/A	TSP			0.66
Shaft:	N/A	Fan Design Data		Filter SP			0.025
Vol:	N/A	CFM:	1800	CFM Total			1855
Fixed:	N/A	SP:	7	CFM RA			1330
		RPM:	N/A	CFM OA			525
		BHP:	N/A				
		OSA:	N/A				

NO.	TYPE	SIZE	Design		TEST 1		TEST 2		TEST 3	
			CFM	CFM	CFM	CFM	CFM	CFM		
114	71	S	12	460	420	525	465			
114	72	S	12	460	390	495	490			
140	73	S	12	455	545	460	460			
134	74	S	6	30	110	30	35			
133	75	S	6	85	105	85	85			
101	76	S	8	140	275	150	150			
114	77	S	8	170	135	175	170			
TOTAL				1800	1980	1920	1855			
114	78	R	12	460	690	680	465			
144	79	R	14	840	785	770	835			
134	80	R	6	20	170	170	30			
TOTAL				1320	1645	1620	1330			
OSA				480	335	300	525			

Remarks: * EXISTING UNIT HAS NO NAMEPLATE.

AIRTEX AIR CONDITIONING AND HEATING, INC. - 3199 Fitzgerald Road - Rancho Cordova, CA 95742
 (916) 852-8672 Fax (916) 852-8459 - Lic# 614060

AIRTEX

Job No: WF-33 Area Served: QUIET, CHILDS PLAY, READING, OFFICE
 Date: May 06, 2004 Page: 5 of 15 Unit No: HP-5

Motor Nameplate Data		Unit Nameplate Data		Data Item	Test 1	Test 2	Test 3
MFR:	GE	MFR:	YORK	Volts			211
FR:	N/A	M/N:	B2SP060A25B	AMPS			4.7
HP:	3/4 V: 208/230	S/N:	NKPM292779	BHP			N/A
FLA:	6 PH: 1	Sheave Data: B/pwr:		RPM			HI SPD
SF:	1 RPM: 1075	P/N:	N/A	SP -			0.15
Sheave Data		Shaft:	N/A	SP +			0.47
P/N:	N/A	Belts:	N/A	TSP			0.62
Shaft:	N/A	Fan Design Data		Filter SP			0.03
Adj:	N/A	CFM:	1800	CFM Total			1815
Fixed:	N/A	SP:	0.7	CFM RA			1480
		RPM:	N/A	CFM OA			330
		BHP:	N/A				
		OSA:	N/A				

Room	Opening			Factor	Design		Test 1		Test 2		Test 3	
	No.	Type	Size		CFM	CFM	CFM	CFM	CFM	CFM	CFM	CFM
112	15	S	12		480		445		475		485	
112	16	S	12		480		560		560		495	
113	17	S	10		210		225		225		200	
117	18	S	6		30		35		35		30	
144	19	S	10		360		330		330		365	
116	20	S	8		135		110		110		130	
115	21	S	8		105		105		105		110	
TOTAL					1800		1810		1840		1815	
115	22	R	6		85		90		75		90	
112	23	R	14		790		760		660		775	
116	24	R	8		120		225		190		130	
143	25	R	10		335		360		315		335	
113	26	R	10		145		400		350		145	
TOTAL					1475		1835		1590		1475	
OSA					325		245		250		340	

Remarks: _____

AIRTEX AIR CONDITIONING AND HEATING, INC. - 3199 Fitzgerald Road - Rancho Cordova, CA 95742
 (916) 852-8672 Fax (916) 852-8459 - Lic# 614060

AIRTEX

Job No: WF-33 Area Served: ACTIVITY ROOM
 Date: May 06, 2004 Page: 6 of 15 Unit No: AC-1

Motor Nameplate Data		Unit Nameplate Data		Blade Type	Test 1	Test 2	Test 3
MFR:	GE	MFR:	TRANE	Volts			211
FR:	56	M/N:	YSC036A2RLA1302 0000000 80A	AMPS			2.2
HP:	1 V: 200-230/460	S/N:	353100760L	BHP			N/A
FLA:	4 PH: 3	Shaft Data Blower		RPM			850
SF:	6 RPM: 1725	P/N:	AK-49	SP -			0.22
Shaft Data		Shaft:	3/4	SP +			0.15
P/N:	SVL34	Belts:	AX-26	TSP			0.37
Shaft:	5/8	Fan Design Data		Filter SP			0.03
Adj:	70%	CFM:	1200	CFM Total			1290
Fixed:	N/A	SP:	0.8	CFM RA			1115
		RPM:	N/A	CFM OA			175
		BHP:	0.47				
		OSA:	N/A				

Room	Opening			Factor	Design		Test 1		Test 2		Test 3	
	No.	Type	Size		CFM	GPM	CFM	GPM	CFM	GPM	CFM	GPM
111	1	S	10			400		600		480		435
	2	S	10			400		480		470		430
	3	S	10			400		600		455		425
TOTAL						1200		1680		1405		1290
111	4	R	16			1040		880		1205		1115
OSA						160		800		200		175

Remarks: _____

AIRTEX AIR CONDITIONING AND HEATING, INC. - 3199 Fitzgerald Road - Rancho Cordova, CA 95742
 (916) 852-8672 Fax (916) 852-8459 - Lic# 614060

AIRTEX

Job No: WF-33 Area Served: ADMINISTRATION, ENTRY
 Date: May 06, 2004 Page: 8 of 15 Unit No: AC-3

Motor Nameplate Data		Unit Nameplate Data		Data Item	Test 1	Test 2	Test 3
MFR:	GE	MFR:	TRANE	Volts			215
FR:	56	M/N:	YSC048A3KLA1602	AMPS			2.3
HP:	1 V: 200-230/480	S/N:	402100404L	BHP			N/A
FLA:	4 PH: 3	Sheave Data Blower:		RPM			860
SF:	6 RPM: 1725	P/N:	AK-44	SP -			0.3
Sheave Data		Shaft:	3/4	SP +			0.29
P/N:	SLV34	Belts:	AX-26	TSP			0.59
Shaft:	5/8	Fan Design Data		Filter SP			0.04
Adj:	50%	CFM:	1440	CFM Total			1510
Fixed:	N/A	SP:	0.8	CFM RA			1390
		RPM:	N/A	CFM OA			120
		BHP:	0.69				
		OSA:	N/A				

Room	Opening			Factor	Design		Test 1		Test 2		Test 3	
	No.	Type	Size		CFM	CFM	CFM	CFM	CFM	CFM	CFM	CFM
	61	S	10		300		475		300		320	
	62	S	8		180		430		180		190	
	63	S	12		440		465		415		455	
	64	S	10		290		380		300		310	
	65	S1	12X12		230		350		230		235	
TOTAL					1440		2100		1425		1510	
	66	R1	12X12		215		325		215		225	
	67	R	10		300		250		225		305	
	68	R	8		165		240		165		170	
	69	R	10		280		400		285		300	
	70	R	10		365		475		370		390	
TOTAL					1325		1690		1260		1390	
OSA					115		410		165		120	

Remarks:

AIRTEX AIR CONDITIONING AND HEATING, INC. - 3199 Fitzgerald Road - Rancho Cordova, CA 95742
 (916) 852-8672 Fax (916) 852-8459 - Lic# 614060

AIRTEX

Job No: WF-33 Area Served: BEDROOMS, SOUTH
 Date: May 06, 2004 Page: 9 of 15 Unit No: AC-4

Motor Nameplate Data		Unit Nameplate Data		Data Item	Test 1	Test 2	Test 3
MFR:	GE	MFR:	TRANE	Volts			211
FR:	56	M/N:	YSC060A3RMA190208 B0	AMPS			2.9
HP:	1 V: 200-230/480	S/N:	353100778L	BHP			N/A
FLA:	4 PH: 3	Shower Data - Blower		RPM			1040
SF:	6 RPM: 1725	P/N:	AK-41	SP -			0.3
Shower Data		Shaft:	3/4	SP +			0.38
P/N:	SVL34	Belts:	AX-26	TSP			0.68
Shaft:	5/8	Fan Design Data		Filter SP			0.03
Adj:	50%	CFM:	2000	CFM Total			2120
Fixed:	N/A	SP:	0.8	CFM RA			1605
		RPM:	N/A	CFM OA			515
		BHP:	1.27				
		OSA:	N/A				

Room	Opening			Factor	Design		Test 1		Test 2		Test 3	
	No.	Type	Size		FPM	CFM	FPM	CFM	FPM	CFM	FPM	CFM
122	33	S2	12X12			265		550		335		290
123	34	S2	14X14			485		625		560		520
124	35	S2	12X12			430		460		490		450
125	36	S2	12X12			335		420		370		325
126	37	S2	14X14			485		450		585		535
TOTAL						2000		2505		2340		2120
144	38	R	18			1490		1935		1800		1605
OSA						510		570		540		515

Remarks: _____

AIRTEX AIR CONDITIONING AND HEATING, INC. - 3199 Fitzgerald Road - Rancho Cordova, CA 95742
 (916) 852-8672 Fax (916) 852-8459 - Lic# 614060

AIRTEX

Job No: WF-33 Area Served: DINING ROOM
 Date: May 06, 2004 Page: 10 of 15 Unit No: AC-5

Motor Nameplate Data			Unit Nameplate Data			Data Item			Test 1	Test 2	Test 3
MFR:	GE		MFR:	TRANE		Volts					211
FR:	56H2		M/N:	YSC120A3RHA18D1		AMPS					7.3
HP:	3	V: 208-230/460	S/N:	3531D0682L		BHP					M/A
FLA:	9.4	PH: 3	Sheave Data Blower			RPM					950
SF:	1.15	RPM: 1725	P/N:	AK-59		SP -					0.6
Shaft Data			Shaft:	1		SP +					0.42
P/N:	SVL44		Belts:	AX-35		TSP					1.02
Shaft:	7/8		Fan Design Data			Filter SP					0.05
Adj:	50%		CFM:	4080		CFM Total					4390
Fixed:	N/A		SP:	0.8		CFM RA					3220
			RPM:	N/A		CFM OA					1170
			BHP:	2.2							
			OSA:	N/A							

Room	Opening			Factor	Design		Test 1		Test 2		Test 3	
	No.	Type	Size		FPM	CFM	FPM	CFM	FPM	CFM	FPM	CFM
109	5	S	14			695		920		760		755
	6	S	14			695		950		750		750
	7	S	14			695		820		750		745
	8	S	12			605		515		680		655
	9	S	14			695		940		725		735
	10	S	14			695		1020		750		750
TOTAL						4080		5165		4395		4390
TOTAL	11	R	12			425		620		485		450
	12	R	16			900		1105		870		985
	13	R	14			655		790		625		695
	14	R	16			1020		1955		1500		1090
TOTAL						3000		4470		3480		3220
OSA						1080		695		915		1170

Remarks:

AIRTEX AIR CONDITIONING AND HEATING, INC. - 3199 Fitzgerald Road - Rancho Cordova, CA 95742
 (916) 852-8672 Fax (916) 852-8459 - Lic# 614060

AIRTEX

Job No: WF-33 Area Served: KITCHEN
 Date: May 06, 2004 Page: 11 of 15 Unit No: AC-6

Motor Nameplate Data		Unit Nameplate Data		Data Item	Test 1	Test 2	Test 3
MFR:	GE	MFR:	TRANE	Volts			211
FR:	56HZ	M/N:	YSC12DA3RLA18D	AMPS			6.7
HP:	3 V: 208-230/460	S/N:	349102223L	BHP			N/A
FLA:	9.4 PH: 3	Shaver Data Blower		RPM			850
SF:	1.15 RPM: 1725	P/N:	AK-59	SP -			38
Shaver Data		Shaft:	1	SP +			0.22
P/N:	SVL44	Belts:	AX-35	TSP			0.6
Shaft:	7/8	Fan Design Data		Filter SP			0.06
Adj:	50%	CFM:	4000	CFM Total			1300
Fixed:	N/A	SP:	0.8	CFM RA			3555
		RPM:	N/A	CFM OA			630
		BHP:	1.89				
		OSA:	N/A				

Room	Opening			Factor	Design		Test 1		Test 2		Test 3	
	No.	Type	Size		CFM	CFM	CFM	CFM	CFM	CFM	CFM	CFM
108	81	S	14			800		990		940		855
108	82	S	14			800		1000		920		845
108	83	S	14			800		915		920		825
108	84	S	14			800		850		940		835
108	85	S	14			800		1055		940		825
TOTAL						4000		4810		4660		4185
108	86	R	18			1470		1690		1485		1385
108	87	R	18			1000		990		870		870
108	88	R	18			1470		1375		1200		1300
TOTAL						3940		4055		3555		3555
OSA						60		755		630		630

Remarks: W/ ECONO. @ MIN. ADJ. POSITION UNIT IS BRINGING IN 630 CPM OSA, 570 CFM ABOVE DESIGN SET EF-1 @ 570 CPM HIGHER THAN DESIGN TO COMPENSATE.

AIRTEX AIR CONDITIONING AND HEATING, INC. - 3199 Fitzgerald Road - Rancho Cordova, CA 95742
 (916) 852-8672 Fax (916) 852-8459 - Lic# 614060

