

R-61

W $\frac{1}{2}$  Lot 15 **BUILDING DIVISION—BUILDING INSPECTOR'S REPORT CARD** F813-869

City Farms **TYPE BUILDINGS** \$28.50

|                             |   |
|-----------------------------|---|
| <b>PERMIT NO.</b><br>D-3683 | <b>LOCATION</b><br>2671-<br><del>2691</del> - 29th Avenue A-3 |
| <b>DATE</b><br>Oct. 19, 59  | <b>PURPOSE</b> Const. dwelling & garage                       |
| <b>ZONE</b><br>R-1          | <b>OWNER</b> Guy & Crowe 1531 Dickson St.                     |
|                             | <b>ARCH'T</b>   |
|                             | <b>CONT'R</b> Owner GA 8-2012                                 |

|                       |                     |                   |              |                              |
|-----------------------|---------------------|-------------------|--------------|------------------------------|
| <b>VAL.</b> \$10,000. | <b>STORIES</b><br>1 | <b>ROOMS</b><br>6 | <b>APTS.</b> | 264 Gar. SIZE<br>1003 Sq.ft. |
|-----------------------|---------------------|-------------------|--------------|------------------------------|

| INSP. | DATE     | INSPECTOR |
|-------|----------|-----------|
| FORM  | 10-21-59 | Calloway  |
| JOIST | 10-29-59 | Calloway  |
| FRAME | 12-18-59 | Calloway  |
| LATH  | 12-24-59 | Calloway  |
| FINAL | 2-29-60  | Coert     |

| DATE     | SPECIAL CONDITIONS OF WORK—REMARKS  |
|----------|---|
| 10-28-59 | P.T. Not ready. Double Bond joint. No. + So. walls. Calloway.   |
| 12-9-59  | P.T. No fire place ties. No spark arrester. Heater flue to close to ceiling joint. Calloway.          |
|          |   |
|          |   |
|          |   |
|          |   |
|          | <p data-bbox="302 1002 450 1053">COMPLETE AND OK</p> <p data-bbox="1290 1030 1438 1057">INSPECTOR</p> |