

729' (23) 125 58 74  
**APPLICATION FOR PERMIT TO BUILD**

Street No. 908-57 525 Lot 4, 10, 11, 12 Block 57  
 Owner H Miller Address 4927  
 Architect \_\_\_\_\_ Address \_\_\_\_\_  
 Contractor Quinn Address \_\_\_\_\_  
 Kind of Building 2 story city & P.C. by garage

Permit 4432  
 Date 2/7/27  
 District 5

Foundation Concrete 15x12  
 Posts \_\_\_\_\_ Girder 4x6 Span 12 Mud Sills 2x6  
 1st Floor 2nd Floor 3rd Floor 4th Floor 5th Floor 6th Floor

|                        |               |  |  |                   |  |  |
|------------------------|---------------|--|--|-------------------|--|--|
| Joists                 | <u>2x8-16</u> |  |  |                   |  |  |
| Max. Span              | <u>12</u>     |  |  |                   |  |  |
| Bearing Partitions     | <u>2x4</u>    |  |  |                   |  |  |
| Non Bearing Partitions | <u>2x2</u>    |  |  |                   |  |  |
| Story Height           | <u>8'6"</u>   |  |  |                   |  |  |
| Outside Walls          | <u>2x4</u>    |  |  | <u>Water 1450</u> |  |  |

Ceiling Joists 2x4 Span \_\_\_\_\_  
 Roof Shingle Rafters 2x4  
 Water Heater Ward Chimney Brick  
 Size of Building—Length 30 Width 26 Height 17'6"

It is hereby agreed that this building will be constructed in conformity with the Ordinances of the City of Sacramento and the Laws of the State of California.  
 ESTIMATED COST, \$ 2200  
 Plans must be submitted.  
M. H. L. Cook  
 Owner or Owner's Representative.

Water - Semi Pq  
Lining up Keys 3/4" inside  
on side door

JAN 5. 1928. # The Inspector's House Completed  
A W Campbell