

BUILDING DIVISION-BUILDING INSPECTOR'S REPORT CARD

TYPE BUILDINGS

PERMIT No. <i>A-1801</i>	LOCATION <i>1012 J Pt.</i>	PHONES
DATE <i>7/3/34</i>	PURPOSE <i>Hang sign</i>	
ZONE <i>Gen Com</i>	OWNER <i>Belt Edge Cafe</i>	
	ARCH'T	
	CONT'R <i>Elec. Sign Rev Co</i>	
VAL. <i>100.00</i>	STORIES	ROOMS
		APTS.
		SIZE

Light Shafts		Elevator Shafts	
Vent Shafts		Boiler Rooms	
Owner's Inspector		Sprinkler System	
Lath		Gas Vents	
Fire Escapes		Chimneys	
Stand Pipes		Skylights	

DATE	CONDITION OF WORK-REMARKS
7/6/34	Inspected New Horizontal Electric Sign
	hung 10 ft above sidewalk and more than
	3 ft from face of curb. Sign is properly
	hung and braced with guy wires.
	O.K. A.H. Campbell
7/6/34	COMPLETE AND O.K. <i>Allen A. Campbell</i> INSPECTOR