

BUILDING DIVISION—BUILDING INSPECTOR'S REPORT CARD

TYPE VII BUILDINGS

PERMIT NO. <i>5761</i>	LOCATION <i>122A-41ST ST</i>		
DATE <i>JAN 11. 1930</i>	PURPOSE <i>FINISH OFF ATTIC FOR CHILDREN'S PLAY ROOM</i>	ROOMS	APTS.
	OWNER <i>DR. BEATTIE</i>	PHONE	
ZONE <i>1-Family Dist</i>	ARCH'T		
	CONT'R <i>W. B. LA DUE</i>		
	VAL. <i>200⁰⁰</i>	STORIES <i>1</i>	SIZE

FOUNDATION	STORY	BSMT	1	2	3	ROOF		
EX WALL	Joists						Chimneys	Cement Tests
	Beams and Girders						Fire Place	
Int Wall	Studs and Columns						Gas Water Heater	
	Bridging Fire Stops						Heater Closet	
Piers	Fire Escape Stand Pipes						Furnace	Window Courts
	Metal Lath						Boiler Room	
	Stairs						Elevator Shaft	

DATE	CONDITION OF WORK—REMARKS
4/15/30	Inspected Attic finished off for Children's
	Play-Rm. Used 2x3 -16" centers crosswise
	of present 2x6 Ceiling Joists. T&G. Plm over
	Installed 2x4 COLLAR BEAMS TO RAFTERS
	T. & G. WALLS & CEILING - OK. Ad Campbell
	<p style="text-align: center;">COMPLETED AND O.K.</p> <p style="text-align: right;">INSPECTOR</p>

DATE	CONDITION OF WORK—REMARKS
	<p data-bbox="327 965 501 1017">COMPLETED AND O.K.</p> <p data-bbox="1235 994 1398 1017">INSPECTOR</p>