

CITY OF SACRAMENTO

Permit No: 0517697

1231 I Street, Sacramento, CA 95814

Insp Area: 4

Thos Bros: 298A1

Site Address: 1651 EXPOSITION BL SAC

Sub-Type: REM

Parcel No: 277-0273-005

Housing (Y/N): N

CONTRACTOR

PANATTONI CONSTRUCTION INC
8745 FOLSOM BL
SAC CA 95826

OWNER

PANATTONI DEV.
8401 JACKSON RD.
SACRAMENTO 95826

ARCHITECT

FORRAIR WILLIAMS ARCHITECTS
1418 12TH ST
SACRAMENTO CA 98814

Nature of Work: 23745 SQFT INTERIOR REMODEL

CONSTRUCTION LENDING AGENCY: I hereby affirm under penalty of perjury that there is a construction lending agency for the performance of the work for which this permit is issued (Sec. 3097, Civ. C).

Lender's Name

Lender's Address

LICENSED CONTRACTORS DECLARATION: I hereby affirm under penalty of perjury that I am licensed under provisions of Chapter 9 (commencing with section 7000) of Division 3 of the Business and Professions Code and my license is in full force and effect.

X License Class B License Number 759899 Date 1/6/06 Contractor Signature [Signature]

OWNER-BUILDER DECLARATION: I hereby affirm under penalty of perjury that I am exempt from the contractors License Law for the following reason (Sec. 7031.5, Business and Professions Code; any city or county which requires a permit to construct, alter, improve, demolish, or repair any structure, prior to its issuance, also requires the applicant for such permit to file a signed statement that he or she is licensed pursuant to the provisions of the Contractors License Law (Chapter 9 (commencing with Section 7000) of Division 8 of the Business and Professions Code) or that he or she is exempt therefrom and the basis for the alleged exemption. Any violation of Section 7031.5 by any applicant for a permit subjects the applicant to a civil penalty of not more than five hundred dollars (\$500.00);

I, as a owner of the property, or my employees with wages as their sole compensation, will do the work, and the structure is not intended or offered for sale (Sec. 7044, Business and Professional Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who does such work himself or herself or through his/her own employees, provided that such improvements are not intended or offered for sale. If, however, the building or improvement is sold within one year of completion, the owner-builder will have the burden of proving that he/she did not build or improve for the purpose of sale.)

I, as owner of the property, am exclusively contracting with licensed contractors to construct the project (Sec. 7044, Business and Professions Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who contracts for such projects with a contractor(s) licensed pursuant to the Contractors License Law).

I am exempt under Sec. B & PC for this reason:

PAID
CITY OF SACRAMENTO

Date

Owner Signature

JAN 06 2006

IN ISSUING THIS BUILDING PERMIT, the applicant represents, and the city relies on the representation of the applicant, that the applicant verified all measurements and locations shown on the application or accompanying drawings and that the improvements constructed does not violate any law or private agreement relating to permissible or prohibited locations for such improvements. This building permit does not authorize any illegal location of any improvement or the violation of any private agreement relating to location of improvements.

I certify that I have read this application and state that all information is correct. I agree to comply with all city and county ordinances and state laws relating to building construction and hereby authorize representative(s) of this city to enter upon the abovementioned property for inspection purposes.

X Date 1/6/06 Applicant/Agent Signature [Signature]

WORKER'S COMPENSATION DECLARATION: I hereby affirm under penalty of perjury one of the following declarations:

I have and will maintain a certificate of consent to self-insure for workers' compensation as provided for by Section 3700 of the Labor Code, for the performance of work for which the permit is issued.

X RB I have and will maintain workers' compensation insurance, as required by Section 3700 of the Labor Code, for the performance of the work for which this permit is issued. My workers' compensation insurance carrier and policy number are:

Carrier STATE FUND

Policy Number 713-6577-002

Exp Date 09/01/2006

(This section need not be completed if the permit is for \$100 or less) I certify that in the performance of the work for which this permit is issued, I shall not employ any person in any manner so as to become subject to the workers' compensation laws of California and agree that if I should become subject to the workers' compensation provisions of Section 3700 of the Labor Code, I shall forthwith comply with those provisions.

X Date 1/6/06 Applicant Signature [Signature]

WARNING: FAILURE TO SECURE WORKER'S COMPENSATION COVERAGE IS UNLAWFUL AND SHALL SUBJECT AN EMPLOYER TO CRIMINAL PENALTIES AND CIVIL FINES UP TO ONE HUNDRED THOUSAND DOLLARS (\$100,000) IN ADDITION TO THE COST OF COMPENSATION, DAMAGES AS PROVIDED FOR IN SECTION 3706 OF THE LABOR CODE, INTEREST AND ATTORNEY'S FEE.

THIS PERMIT SHALL EXPIRE BY LIMITATION IF WORK IS NOT COMMENCED WITHIN 180 DAYS.



VAV AIR DISTRIBUTION REPORT

Job Name: NATIONWIDE EXPANSION 2ND FLOOR
 Job Number: 5115.10 Page 1 of 5
 Date: 1-23-06
 Tech: JOE & BRENT

AREA	RAW SENSOR READING				No.	OUTLET Type	Size	H Max	DESIGN		PRELIMINARY		FINAL
	ZERO	OPEN	MAX	MIN					C Min	C Max			C Max
VAV 3-2					1		8"			150	180	160	155
					2		8"			150	120	140	145
								100	100	300	300	300	300
VAV 3-3					3		6"			100	90		110
					4		8"			200	10		200
					5						200		200
					6						200		200
					7						150		190
					8						150		190
								340	340	1100	790		1090
VAV 3-4					9		10"			275	250		270
					10						300		255
					11						270		260
					12						270		265
								370	370	1100	1050		1050
VAV 3-5					13		6"			50	50		50
					14		10"			225	300		235
					15					275	250		270
					16					275	300		270
					17					275	300		270
								370	370	1100	1200		1095

NOTES:



VAV AIR DISTRIBUTION REPORT

265
180

Job Name: NATIONWIDE EXPANSION 3RD FLOOR
 Job Number: 5115.10
 Date: 1-23-06
 Tech: JOE & BRENT

AREA	RAW SENSOR READING				OUTLET			DESIGN			PRELIMINARY	FINAL
	ZERO	OPEN	MAX	MIN	No.	Type	Size	H Max	C Min	C Max		C Max
VAV 3-6					18	SI	8"			200		210
					19	↓	↓			200		200
					20	↓	↓			200		200
					21	↓	↓			200		200
								340	340	800		810
VAV 3-7					22	SI	10"			250	300	260
					23	↓	↓			330	260	260
					24	↓	↓			270	245	245
					25	↓	↓			280	260	260
								340	340	1000	1180	1025
VAV 3-8					26	SI	10"			250	240	240
					27	↓	↓			250	240	240
								170	170	500	480	480
VAV 3-9					28	SI	8"			200		160
					29	↓	↓			200		150
					30	↓	↓			300		270
					31	↓	↓			300		270
								340	340	1000		850
VAV 3-10					32	SI	10"			300	240	300
					33	↓	↓			300	280	300
					34	↓	↓			300	230	275
					35	↓	↓			300	260	300
								400	400	1200	1010	1175

NOTES:




VAV AIR DISTRIBUTION REPORT

Job Name: NATIONWIDE EXPANSION 3RD FLOOR
 Job Number: 5115.10
 Date: 1-23-06
 Tech: JOE & BRENT

AREA	RAW SENSOR READING				OUTLET			DESIGN			PRELIMINARY	FINAL
	ZERO	OPEN	MAX	MIN	No.	Type	Size	H Max	C Min	C Max		C Max
VAV												
3-11					36		8"			150		160
					37		↓			150		160
					38		10"			250		250
								185	185	550		570
VAV												
3-12					39		6"			100		90
					40		10"			225		220
					41		↓			225		230
					42		↓			225		230
					43		↓			225		240
					44		↓			225		240
					45		↓			225		240
								480	480	1450		1490
VAV												
3-13					46		8"			200		205
					47		↓			200		195
									135	400		400
VAV												
3-14					48		6"			100		95
					49		10"			200		195
					50		↓			250		240
					51		↓			250		240
								270	270	800		770
VAV												
3-15					52		8"			200		210
					53		↓			200		205
								300	300	400		415

NOTES:




VAV AIR DISTRIBUTION REPORT

Job Name: NATIONWIDE EXPANSION 3RD FLOOR
 Job Number: 5115.10
 Date: 1-23-06 Page 4 of 5
 Tech: JOE & BRENT

AREA	RAW SENSOR READING				OUTLET			DESIGN			PRELIMINARY	FINAL
	ZERO	OPEN	MAX	MIN	No.	Type	Size	H Max	C Min	C Max		C Max
VAV												
3-16					54		8"			200		220
					55		↓			200		210
								300	300	400		430
VAV												
3-17					56		10"			240	250	240
					57		↓			330		245
					58		↓			230		240
					59		↓			300		235
					60		↓			300		240
								400	400	1200	1410	1200
VAV												
3-18					61		6"			100	180	110
					62		8"			200	230	150
					63		↓			310		200
					64		↓			280	190	195
					65		10"			300	420	290
					66		↓			300	470	300
									435	1300	1890	1305

NOTES:



VAV AIR DISTRIBUTION REPORT

Job Name: NATIONWIDE EXPANSION 2ND FLOOR
 Job Number: 5115.10
 Date: 1-23-06 Page 5 of 5
 Tech: JOE & BRENT

AREA	RAW SENSOR READING				OUTLET			DESIGN			PRELIMINARY	FINAL		
	ZERO	OPEN	MAX	MIN	No.	Type	Size	H Max	C Min	C Max		C Max		
AH2					67	S1	10"			300	180	310	310	
					68						410	300	330	
					69						280	380	320	
					70						450	340	320	
					71						280	290	310	
					72		↓			↓	320	280	300	
					73		8"			↓	200	210	185	195
											2000	2130		2085
AH3					74	S1	8"			200	220	220	220	
					75		10"			300	270	330	330	
					76						330	320	320	
					77						420	300	300	
					78						340	310	310	
					79						300	300	300	
					80		↓			↓	250	310	310	
											2000	2130	2090	2090
AH4					81	S6	8"			200	260	210	210	
					82	S1	10"			233	0	240	240	
					83		↓			233	280	240	240	
					84					333	470	315	315	
					85						280	325	325	
					86						580	335	335	
					87		↓			↓	120	325	325	
											1998	1990	1990	1990

NOTES: