

BUILDING DIVISION—BUILDING INSPECTOR'S REPORT CARD

TYPE VII BUILDINGS

| | | | |
|----------------------------------|--------------------------------------|----------------|------------------------------|
| PERMIT NO. <i>5488</i> | LOCATION <i>1736-49 St</i> | | |
| DATE <i>11/4/29</i> | PURPOSE <i>Pr Garage</i> | ROOMS | APTS. |
| ZONE <i>1</i> | OWNER <i>JR Home</i> | | PHONE |
| | ARCH'T | | |
| | CONT'R <i>Quinn</i> | | |
| | VAL. <i>100</i> | STORIES | SIZE <i>9 x 24</i> |

| FOUNDATION | STORY | BSMT | 1 | 2 | 3 | ROOF | | |
|-----------------|-------------------------|------|---|---|---|------|------------------|---------------|
| EX WALL | Joints | | | | | | Chimneys | Cement Tests |
| | Beams and Girders | | | | | | Fire Place | |
| Int Wall | Studs and Columnna | | | | | | Gas Water Heater | |
| | Bridging Fire Stops | | | | | | Heater Closet | |
| Piers | Fire Escape Stand Pipes | | | | | | Furnace | Window Courts |
| | Metal Lath | | | | | | Boiler Room | |
| | Stairs | | | | | | Elevator Shaft | |



| DATE | CONDITION OF WORK—REMARKS |
|----------|---|
| 11/13/29 | Made Inspection of Addition to rear of Dredge. |
| | Some built on Pitt. Sills. ^{Muds too far apart. No Bldg Paper} _{fracts of concrete} |
| | Older camp old wood shed to be moved around to be from Dredge |
| | Not ready for frame until work is corrected. X |
| | A.W. Campbell |
| | |
| | |
| | |
| | |
| | |
| | |
| | <p style="text-align: center;">COMPLETED AND O.K.</p> <p style="text-align: right;">INSPECTOR</p> |

