

R-136 F 604-609

E $\frac{1}{2}$ Lt. 2		BUILDING DIVISION — BUILDING INSPECTOR'S REPORT CARD \$139.50			
23-24-th St.-F-G St.		TYPE BUILDINGS <i>7449-7450 file</i>			
PERMIT NO. E-6176	LOCATION 2314-F Street		A-2		
DATE Feb. 10, 64	PURPOSE Const new 9-Unit Apartment House		OWNER Kenneth Valentine 6931 Middlecoff Way		
ZONE R-4	ARCH'T R. Wm. Isacson		CONTR Lee Basford 6321 Eichler Way		
VAL. \$47,200.	STORIES 2	ROOMS	APTS. 9	5550 S.F. SIZE	
INSP.	DATE	BLDG. TYPE V	OCCUPANCY GROUP H-2	PHONE (O) (C)	
FORM	<i>2-12-64</i>	<i>Prolo</i>			
JOIST	<i>3-25-64</i>	<i>Barbato</i>			
FRAME	<i>4-7-64</i>	<i>Barbato</i>			
SHEET ROCK	<i>4-17-64</i>	<i>Doug Fuller</i>			
FINAL	<i>7-9-64</i>	<i>[Signature]</i>	<i>Int Com</i>		

DATE	SPECIAL CONDITIONS OF WORK — REMARKS
2-11-64	PT Not ready Barlato
2-21-64	H-Elw. conduit can not be supported with 2x4 below Barlato
3-4-64	PT mudville & latta not on job Hammer
3-6-64	PT not ready Barlato
3-12-64	OK laundry room & pipes Hammer
3-20-64	not enough studs visible. Change size on front retain retain wall only. too many studs of plywood not code marked Barlato
3-31-64	OK wall & roof nail & 3rd floor plywood nail Barlato
4-3-64	PT front & rear (rear wall connections) incorrect. No according to plan Barlato
4-16-64	COMPLETE AND OK PT. no cad no plans Court
	INSPECTOR