

BUILDING DIVISION-BUILDING INSPECTOR'S REPORT CARD

TYPE BUILDINGS

PERMIT NO. <i>717 Ch 9</i>	LOCATION <i>2209 9th</i>
DATE <i>4/25/30</i>	PURPOSE <i>Gen Rep Iron & Steel</i>
OWNER <i>P. Roomanson</i>	PHONES
ARCHT	
CONT-R <i>Miller Jan</i>	<i>Owner</i>

VAL. <i>Under 20 -</i>	STORIES	ROOMS	APTS.	SIZE
---------------------------	---------	-------	-------	------

Light Shafts		Elevator Shafts	
Vent Shafts		Boiler Rooms	
Owner's Inspector		Sprinkler System	
Lath		Gas Vents	
Fire Escapes		Chimneys	
Stand Pipes		Skylights	

DATE	CONDITION OF WORK-REMARKS
4/24/31	<p>Made Inspection of Repairs being made to front Steps. Found timbers affected by "TERMITES" Notified Owner to remove all wood affected and replace with new material. Also to get this No-Charge Permit. <i>Al Campbell</i></p>
	<p>COMPLETE AND O.K.</p>
	<p>INSPECTOR</p>