

CITY OF SACRAMENTO
1231 I Street, Sacramento, CA 95814

Permit No: 9909367
Insp Area: 3

Site Address: 4517 FRANKLIN BL SAC
Parcel No: 020-0202-007

Sub-Type: REM
Housing (Y/N): N

CONTRACTOR
MIDCAL ELECTRIC CO
6797 ORLEANS WY
SAC CA 95831

OWNER
STICKEL HANS G/ROSEMARIE R
4517 FRANKLIN BL
SACRAMENTO CA 95820

ARCHITECT

Nature of Work: UPGRADE SERVICE FROM 100 AMP 3PHASE TO 400 AMP 3PHASE,
UPGRADE PANEL 'C' TO 125 AMP

CONSTRUCTION LENDING AGENCY: I hereby affirm under penalty of perjury that there is a construction lending agency for the performance of the work for which this permit is issued (Sec. 3097, Civ. C).

Lender's Name _____ Lender's Address _____

LICENSED CONTRACTORS DECLARATION: I hereby affirm under penalty of perjury that I am licensed under provisions of Chapter 9 (commencing with section 7000) of Division 3 of the Business and Professions Code and my license is in full force and effect.

License Class: 70 License Number: 506411 Date: 8/20/99 Contractor Signature: [Signature]

OWNER-BUILDER DECLARATION: I hereby affirm under penalty of perjury that I am exempt from the contractors License Law for the following reason (Sec. 7031.5, Business and Professions Code: any city or county which requires a permit to construct, alter, improve, demolish, or repair any structure, prior to its issuance, also requires the applicant for such permit to file a signed statement that he or she is licensed pursuant to the provisions of the Contractors License Law (Chapter 9 (commencing with Section 7000) of Division 8 of the Business and Professions Code) or that he or she is exempt therefrom and the basis for the alleged exemption. Any violation of Section 7031.5 by any applicant for a permit subjects the applicant to a civil penalty of not more than five hundred dollars (\$500.00):

____ I, as a owner of the property, or my employees with wages as their sole compensation, will do the work, and the structure is not intended or offered for sale (Sec. 7044, Business and Professional Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who does such work himself or herself or through his/her own employees, provided that such improvements are not intended or offered for sale. If, however, the building or improvement is sold within one year of completion, the owner-builder will have the burden of proving that he/she did not build or improve for the purpose of sale.)

____ I, as owner of the property, am exclusively contracting with licensed contractors to construct the project (Sec. 7044, Business and Professions Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who contracts for such projects with a contractor(s) licensed pursuant to the Contractors License Law).

____ I am exempt under Sec. _____ B & PC for this reason: _____

Date _____ Owner Signature _____

IN ISSUING THIS BUILDING PERMIT, the applicant represents, and the city relies on the representation of the applicant, that the applicant verified all measurements and locations shown on the application or accompanying drawings and that the improvement to be constructed does not violate any law or private agreement relating to permissible or prohibited locations for such improvements. This building permit does not authorize any illegal location of any improvement or the violation of any private agreement relating to location of improvements.

I certify that I have read this application and state that all information is correct. I agree to comply with all city and county ordinances and state laws relating to building construction and hereby authorize representative(s) of this city to enter upon the abovementioned property for inspection purposes.

Date _____ Applicant/Agent Signature _____

WORKER'S COMPENSATION DECLARATION: I hereby affirm under penalty of perjury one of the following declarations:

____ I have and will maintain a certificate of consent to self-insure for workers' compensation as provided for by Section 3700 of the Labor Code, for the performance of work for which the permit is issued.

____ I have and will maintain workers' compensation insurance, as required by Section 3700 of the Labor Code, for the performance of the work for which this permit is issued. My workers' compensation insurance carrier and policy number are:

Carrier: Exempt Policy Number: _____

CITY OF SACRAMENTO
PLANNING AND COMMUNITY SERVICES
AUG 20 1999

(This section need not be completed if the permit is for \$100 or less) I certify that in the performance of the work for which this permit is issued, I shall not employ any person in any manner so as to become subject to the workers' compensation laws of California and agree that if I should become subject to the workers' compensation provisions of Section 3700 of the Labor Code, I shall forthwith comply with those provisions.

X Date: Aug 20 1999 Applicant Signature: [Signature]


WARNING: FAILURE TO SECURE WORKER'S COMPENSATION COVERAGE IS UNLAWFUL AND SHALL SUBJECT AN EMPLOYER TO CRIMINAL PENALTIES AND CIVIL FINES UP TO ONE HUNDRED THOUSAND DOLLARS (\$100,000) IN ADDITION TO THE COST OF COMPENSATION, DAMAGES AS PROVIDED FOR IN SECTION 3706 OF THE LABOR CODE, INTEREST AND ATTORNEY'S FEE.

THIS PERMIT SHALL EXPIRE BY LIMITATION IF WORK IS NOT COMMENCED WITHIN 180 DAYS.

PARALLEL 2 (E)

WEIDNER SIGNAGE

ISSUED




This set of plans and specifications must be kept on the job at all times and it is prohibited to make any changes or alterations without the written permission of the Electrical Division. The approval of this plan and specification is subject to permit or approval by the City Ordinance or State Law.

DATE: 8-20-99
BY: [Signature]

POWER BOY

POWER BOY

Franklin Blvd



The approval of all Electrical work is subject to field inspections

APPROVED PER 1996
NATIONAL ELECTRICAL CODE
AND CITY OF SACRAMENTO
AMENDMENTS:
M. 8-20-99
ELECTRICAL DIVISION

OVERHEAD POINT OF ATTACHMENT

4517 FRANKLIN BLVD

MID CAL ELECTRIC CO.

JOB : WEIDNER SIGNAGE

4517 FRANKLIN BLVD.


ONE LINE POWER

2 - 250 mm AL } 2-2 1/2"
100A

400R 38 100-000

I identify the Hi leg as per code

400R



ISSUED

The approval of all
Electrical work is subject to field
inspections

AUG 11 1949

CITY OF LOS ANGELES
DEVELOPMENT



The set of plans and specifications must be kept on the job at all times and it is unlawful to make any changes or alterations from the original without written permission from the City of Los Angeles.

The contractor shall read this plan and specification carefully and shall verify or approve the same before starting work under State Law.

MID CAL ELECTRIC CO.

JOB : WEIDNER SIGNAGE 4517 FRANKLIN BLVD.

LOAD CALCULATIONS MAIN PANEL A

New

Hiley

PF 424 400 AMP 3 PHASE OVERHEAD FEED

CIRCUIT	BREAKER AMPERAGE	PHASE		
		A	B	C
1 PANEL B	90	50		
2 PANEL B	90		50	
3 PANEL B	90			44.8
4 AIRCOND # 1x 125*	60	55.5		
5 AIRCOND #1	60	55.5		
6 AIRCOND # 2	40	21		
7 AIRCOND # 2	40	21		
8 AIRCOND # 3	60	50		
8 AIRCOND #3	60			50
9 PANEL C	125	110		
10 PANEL C	125			98.2

TOTAL AMPERAGE PER PHASE A236.5 176.5 193

CUSTOMER REQUEST 400 AMP SERVICE

3 SETS PARREL 250 MCM AL

1 SET PARREL 2/0 AL

2 - 2 1/2" ENTRANCE CONDUITS

GROUNDING CONDUCTOR 250 - 94 COPPER

#1/0
~~#2~~

SS

DATE

The approval of all
Electrical work is subject to field
inspections

MID CAL ELECTRIC CO.

JOB : WEIDNER SIGNAGE 4517 FRANKLIN BLVD.

LOAD CALCULATIONA PANEL B

Existing *H. Key*

240 120 VOLT 3 PHASE 90 AMP

CIRCUIT	AMP BREAKER	PHASE		
		A	B	C
1 AIRCOMPRESSOR 10 HP	50 / 3 X 125%	35.6		
2 AIRCOMPRESSOR			35.6	
3 AIRCOMPRESSOR				35.6
4 EXHAUST FAN 3 HP	20/3	9.2		
5 EXHAUST FAN			9.2	
6 EXHAUST FAN				9.2
7 BATH HEATER 1250 W	20/2	5.2		
8 BATH HEATER			5.2	

AMPERAGE PER PHASE

A	B	C
50	50	44.8

3 #2 AL 1 #6 1 1/4" CONDUIT 90 AMP BREAKER

The undersigned
Electrical work is subject to field
inspections

SSUP

This set of plans and specifications must be
kept on the job site and it is understood
to be used only for the purpose of the work
shown on the drawings.

DATE: 1940

PROJECT: WEIDNER SIGNAGE
4517 FRANKLIN BLVD.

MID CAL ELECTRIC CO.

JOB : WEIDNER SIGNAGE 4517 FRANKLIN BLVD.

LOAD CALCULATIONS PANEL C *New*

120 240 VOLTS SINGLE PHASE 125 AMPS

CIRCUIT	AMP BREAKER	PHASE	A	C
1 SIGN	20			6
2 COPIER	20	14		
3 COPIER	20			14
4 LIGHTS	20	12		
5 LIGHTS	20			12
6 LIGHTS	20	12		
7 LIGHTS	20			12
8 LIGHTS	20	12		
9 FURNACE	20			4.2
10 PLUGS	20			
11 PLUG	20			10
12 PLUG	20			
13 PLUG	20			10
14 PLUG	20	10		
15 PLUG	20			10
16 PLUG	20			10
17 PLUG	20			10
18 PLUG	20	10		
19 PLUG	20			10
20 PLUG	20	10		



This set of plans and specifications must be kept on the job at all times and it is unlawful to make any changes or alterations from the original without written permission from the Electrical Division.

I hereby certify that I have read and approved the contents of this plan and specification and that it complies with all applicable codes, ordinances and State laws.

The approval of all Electrical work is subject to field inspections

TOTAL EACH LINE 110 AMPS 98.2 AM

3/0 AL WIRES 1 1/2" CONDUIT 125 AMP CIRCUIT BREAKER