

Q1817215-222

BUILDING DIVISION — BUILDING INSPECTOR'S REPORT CARD \$162.50

TYPE BUILDINGS Q218 7206 file

PERMIT NO. F-2359	LOCATION 700 - J Street	A-2
DATE Nov 19-65	PURPOSE Enc. stairway & install new ext. stairway	
	OWNER Crocker Citizens Bank	same
ZONE C-3	ARCH'T Harry Devine 1012-J St.	
	CONTR Campbell Const. 800-R St.	442-1061

VAL \$61,300.	STORIES	ROOMS	APTS.	SIZE
INSP.	DATE	BLDG. TYPE I	OCCUPANCY GROUP F-2	PHONE (O) (C)
FORM				
JOIST				
FRAME	1-18-66	Dana Fuller		
SHEET ROCK	1-30-66	Callaway 1-30-66 Callaway		
FINAL	6-6-67	Dana Fuller int.		

DATE	SPECIAL CONDITIONS OF WORK — REMARKS
4-4-66	Pt frame - metal studs not fastened to plates. In way to seal off
	dropped ceilings from space in stair well studs
4-23-66	OK frame magazine Callaway
4-27-66	Pt frame - not ready Callaway
5-11-66	OK frame & SR on one side Callaway
5-19-66	OK 1st layer 8 story, south stair well Callaway
5-23-66	OK SR 3rd layer elevator shaft Callaway
11/5/67	COMPLETE PT - Not ready for final AND OK
	INSPECTOR