

**BUILDING DIVISION-BUILDING INSPECTOR'S REPORT CARD**

**TYPE BUILDINGS**

PERMIT NO. 9454 DATE: 5/9/3 ✓ ZONE Multi Fam	LOCATION	2800 Jk St	
	PURPOSE	Stone Exterior	PHONES
	OWNER	Miss Kruger	
	ARCH'T		
	CONT-R	O. L. Yonell	

VAL.	400 -	STORIES	ROOMS	APTS.	SIZE
------	-------	---------	-------	-------	------

Light Shafts		Elevator Shafts	
Vent Shafts		Boiler Rooms	
Owner's Inspector		Sprinkler System	
Lath		Gas Vents	
Fire Escapes		Chimneys	
Stand Pipes		Skylights	

DATE	CONDITION OF WORK--REMARKS
5/9/32	Made Preliminary Insp. Contractor removing all Kellacron Patent Plaster and wood lath and getting ready to put on 7/8" Sheathing & Ply Bldg Paper + 18 gauge Smithing wire for Cement Plaster <sup>1/2" thick</sup>
5/16/32	3 <sup>rd</sup> Insp. EXT LATH IN PLACE OK A.W. Campbell
5/20/32	4 <sup>th</sup> Insp. Re Stuccoing of Grid 17 Bldg. Completed OK
	A.W. Campbell
5/30/32	COMPLETE AND O.K. <i>Allen J. Campbell</i> INSPECTOR