

FORM 1 SUPP. EN 9-54
BUILDING DIVISION-BUILDING INSPECTOR'S REPORT CARD

TYPE BUILDINGS

PERMIT NO. 1960-A	LOCATION 130 - K Street	PHONES
DATE 8/29/34	PURPOSE Repairs to Bldg	
OWNER J. H. Vogel	ARCH'T	
ZONE Gen Com	CONT'R Wm La due	
VAL. 1500	STORIES	ROOMS
		APTS.
		SIZE

Light Shafts		Elevator Shafts	
Vent Shafts		Boiler Rooms	
Owner's Inspector		Sprinkler System	
Lath		Gas Vents	
Fire Escapes		Chimneys	
Stand Pipes		Skylights	

DATE	CONDITION OF WORK-REMARKS
9/5/34	<p>Made Inspection on Repairs to 2 Brick Piers on 2nd St Side of Bldg. Crumbling soft brick replaced with new hard brick and piers cement plastered OK</p> <p style="text-align: right;">H. W. Campbell</p>
9/5/34	<p>COMPLETE AND O.K.</p> <p style="text-align: right;">H. W. Campbell</p> <p style="text-align: right;">INSPECTOR</p>