

*511-7602-108*

W. 79' of **BUILDING DIVISION — BUILDING INSPECTOR'S REPORT CARD** \$43.00

N. 226' of Lot 10  
Johnson Heights **TYPE BUILDINGS** *attached*  
*5112-7497*

PERMIT NO. <b>E-2729</b>	LOCATION <b>428 - Patio Avenue</b>	<b>A-6</b>
DATE <b>Nov. 20-62</b>	PURPOSE <b>Const. dwelling &amp; attached garage</b>	
ZONE <b>R-1</b>	OWNER <b>Hobert Ward</b>	<b>424 - Patio Avenue</b>
	ARCH'T	<b>482-0770</b>
	CON'TR	<b>Cardinal Cont. 6101-Fair Oaks Blvd.</b>

VAL. <b>\$11,800.</b>	STORIES <b>1</b>	ROOMS	APTS.	Carm. SIZE <b>1,106 sq.ft.</b>
-----------------------	---------------------	-------	-------	-----------------------------------

INSP.	DATE	BLDG. TYPE	OCCUPANCY GROUP
FORM	<i>12-5-62</i>	<i>Fuller</i>	
JOIST	<i>12-20-62</i>	<i>Fuller</i>	
FRAME	<i>1-21-63</i>	<i>Court</i>	
SHEET ROCK	<i>2-5-63</i>	<i>Court</i>	
FINAL	<i>10-2-64</i>	<i>Hubbs</i>	<i>notice sent 8-23-63</i>

DATE	SPECIAL CONDITIONS OF WORK — REMARKS
------	--------------------------------------

11-30-62	Pt of plans. Mudsills not laid out (Felled)
----------	--

12-6-62	Red tag - do not do any further work until frost set back
---------	--

12-14-62	Pt of fireplace removed Red tag Subject
----------	--

12-17-62	P.T. fireplace tile nail 1x4 on top of 2x6 siding joint. Chelomay
----------	--

1-31-63	Pt (Firewall) must be nailed with #6 nails. Equest
---------	---

3-15-63	Pt improve driveway. Connect to front porch over above Court.
---------	--

8-22-63	Completed without a frost. And notice Calloway
---------	---

12-27-63	Pattern driveway in 1-24-64 Calloway
----------	--------------------------------------

COMPLETE  
AND OK

INSPECTOR