

7122 7100

BUILDING DIVISION — BUILDING INSPECTOR'S REPORT CARD

\$13.00

TYPE BUILDINGS

PERMIT NO. E-3977		LOCATION 1050 - 47th Street		A-1	
DATE May 23-63		PURPOSE Const. garage to rear of dwelling.			
ZONE R-1		OWNER Jerry Twomey		Same	
ARCH'T		CONTR Owner			
VAL. \$1,200.		STORIES	ROOMS	APTS. 500 sq.ft.	SIZE
INSP.	DATE	BLDG. TYPE		OCCUPANCY GROUP	
FORM	<i>5-29-63</i>	<i>Garage</i>		<i>5-28-63</i>	
JOIST					
FRAME					
SHEET ROCK					
FINAL	<i>3-4-64</i>	<i>McCalloway</i>			



DATE	SPECIAL CONDITIONS OF WORK — REMARKS
5-28-63	Pt. Testing not deep enough. Mud- will not cut and marked for bolts. <i>Anchor</i>
6-6-63	Pt. must replace entire <i>anchors</i> & install for <i>anchors</i> . <i>Anchor</i> <i>Test</i>
8-31-63	Pt. Improper <i>rod bracing</i> <i>Count</i>
COMPLETE AND OK	INSPECTOR

